Date:	05/11/2018	Weather:		Coding:	RZMACP
MH#:	M-1004-038	Owner:	NA	Len. Surveyed:	9.9
P.O.#:		Surveyor:	Jen Costello	Rim to Invert:	9.8
Customer:		Cert. #:	U-907-5518	Wall Material:	Concrete (reinforced)
Street:	Coral Dr. 383' East	of Hillcrest Ave.	Project:	Hobart, IN	
City:	Hobart, IN		GPS Northing:	2913126.669	
Location:			GPS Easting:	2913126.669	
Drain Area:	Northeast		GPS Accuracy:	Sub-Meter	
Cover Shape:	Circular		Evidence of Surcharge:	No	
Cover Size: Comments:	22.5		Potential for Runoff:	None	
O&M Index:	0.00	O&M Quick:	0000	O&M Rating:	0.00
Structural Index:	3.00	Structural Qu	uick: 3200	Structural Rating:	6.00
Overall Index:	3.00	Overall Quic	k: 3200	Overall Rating:	6.00

Position	Code	Observation	Video (sec)	Grade
M-1004-038				
.0	MGO	General Observation	10	NA
3.0	MGO	General Observation	29	NA
3.0	SAV	Surface Aggregate Visible	39	S 3
4.2	FL	Fracture Longitudinal	57	S 3
9.9	MGO	General Observation	82	NA
Camera Direction				




Code: Description:	MGO General Observation
Description.	General Observation
Distance (ft):	0
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	ACCESS MH




Code:	MGO
Description:	General Observation
Distance (ft):	3.0
	-
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	UNDERSIDE OF FRAME

SAV



Description:	Surface Aggregate Visible
Distance (ft):	3.0
Structural Grade:	3
O&M Grade:	0
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	

Code:



Code:	FL
Description:	Fracture Longitudinal
Distance (ft):	4.2
Structural Grade:	3
O&M Grade:	0
Clock Start/From:	8
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description: MGO General Observation

Distance (ft):	9.9
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	END SURVEY