iviannole ins	spection Repor	L			ROBOTIC
Date:	10/05/2022	Weather:		Coding:	RZMACP
MH#:	M-103-014	Owner:	NA	Len. Surveyed:	5.2
P.O.#:		Surveyor:	Jen Costello	Rim to Invert:	6.1
Customer:		Cert. #:	U-907-5518	Wall Material:	Concrete (cast ir place)
Street:	Alley between I-65	and Willow St. 2	Project:	Hobart, IN	
City:	Hobart, IN		GPS Northing:	2293500.402	
Location:	Other		GPS Easting:	2890607.575	
Drain Area:	Northwest		GPS Accuracy:	Sub-Meter	
Cover Shape:	Circular		Evidence of Surcharge:	Νο	
Cover Size: Comments:	24.0		Potential for Runoff:	None	
O&M Index:	2.00	O&M Quick:	2200	O&M Rating:	4.00
Structural Index:	1.67	Structural Qu	iick: 5115	Structural Rating:	10.00
Overall Index:	1.75	Overall Quicl	c: 5122	Overall Rating:	14.00

Position	Code	Observation	Video (sec)	Grade
1-103-014				
0.	MGO	General Observation	10	NA
.0	SRI	Surface Roughness Increased	21	S 1
1.1	MGO	General Observation	37	NA
/1.1	SRV	Surface Reinforcement Visible	49	S 5
3.2	IW	Infil Weeper	65	M 2
5.2	DSF	Deposits Settled Fine	81	M 2
5.2	SRI	Surface Roughness Increased	92	S 1
5.2	MGO	General Observation	102	NA



Code: Description:	MGO General Observation
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	access mh



Code:SRIDescription:Surface Roughness Increased

Distance (ft):	.0
Structural Grade:	1
O&M Grade:	0
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description:	MGO General Observation
Distance (ft):	1.1
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	underside of frame



Code: Description:	SRV Surface Reinforcement Visible
Distance (ft):	1.1
Structural Grade:	5
O&M Grade:	0
Clock Start/From:	3
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code:	IW
Description:	Infil Weeper
Distance (ft):	3.2
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description:	DSF Deposits Settled Fine
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Step: Remarks:	5.2 0 2 12 12 5.000 NO



Code: Description:	SRI Surface Roughness Increased
Distance (ft):	5.2
Structural Grade:	1
O&M Grade:	0
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code:MGODescription:General Observation

Distance (ft):	5.2
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	end of survey