Manhole Inspection Report



Date: **04/18/2018** Weather:

M-103-110 MH#: Owner: NA Len. Surveyed: 9.2 P.O.#: John Kuglmaier Rim to Invert: 10.4 Surveyor: U-1215-07002349 Concrete Customer: Cert. #: Wall Material:

(reinforced)

RZMACP

Coding:

Street: Intersection of Alabama St. and 40th Project: Hobart, IN

City: Hobart, IN GPS Northing: 2889435.374

Location: GPS Easting: 2889435.374

Drain Area: Northwest GPS Accuracy: Sub-Meter

Cover Shape: Circular Evidence of Surcharge: No
Cover Size: 23.0 Potential for Runoff: None

Comments:

2.00 2100 2.00 O&M Index: O&M Quick: O&M Rating: 0.00 0000 0.00 Structural Index: Structural Quick: Structural Rating: 2.00 2100 2.00 Overall Index: Overall Quick: Overall Rating:


Wednesday, May 3, 2023

	Position	Code	Observation	Video (sec)	Grade
M-103-110)				
	.0	MGP	General Photo	10	NA
- 11	2.2	MGP	General Photo	28	NA
	3.8	IS	Infil Stain	45	NA
	7.2	DSF	Deposits Settled Fine	63	M 2
	8.6	MGO	General Observation	78	NA
Camera Direction					



Code:	MGP
Description:	General Photo
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	

2 Wednesday, May 3, 2023



Code: MGP

Description: General Photo

Distance (ft): 2.2
Structural Grade: 0
O&M Grade: 0
Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks:



Code: IS

Description: Infil Stain

Distance (ft): 3.8
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 12
Clock To: 12
1st Value:
2nd Value:

Step: NO

Remarks:

Value Percent:



Code: **DSF**

Description: Deposits Settled Fine

Distance (ft): 7.2
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 12
Clock To: 12
1st Value:

2nd Value:

Value Percent: 5.000 Step: NO

Remarks:

Wednesday, May 3, 2023 3



Code: MGO

Description: General Observation

Distance (ft): 8.6
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: Ins. Comp.

4

Wednesday, May 3, 2023