## **Manhole Inspection Report**



10/05/2022 Coding: Date: Weather: **RZMACP** 

M-203-041 MH#: Owner: NA Len. Surveyed: 9.3 P.O.#: **Todd Machine** Rim to Invert: 10.2 Surveyor:

P0038859-082022 Concrete (cast in Customer: Cert. #: Wall Material:

place)

Street: 38th Ave. 164' West of Maitland St. Project: Hobart, IN

2295209.654 City: Hobart, IN **GPS Northing:** Location: Other GPS Easting: 2892252.55 Northwest Drain Area: GPS Accuracy: **Sub-Meter** 

Cover Shape: Circular Evidence of Surcharge: No Cover Size: 24.0 Potential for Runoff: None

Comments:

2.00 2200 4.00 O&M Index: O&M Quick: O&M Rating: 1.00 1900 9.00 Structural Index: Structural Quick: Structural Rating: 1.18 2219 13.00 Overall Index: Overall Quick: Overall Rating:

| Position | Code | Observation                 | Video (sec) | Grade |
|----------|------|-----------------------------|-------------|-------|
| 203-041  |      |                             |             |       |
| .0       | MGO  | General Observation         | 10          | NA    |
| 0.       | SRI  | Surface Roughness Increased | 21          | S 1   |
| 2.5      | MGO  | General Observation         | 40          | NA    |
| 8.1      | IW   | Infil Weeper                | 65          | M 2   |
| 9.3      | DSF  | Deposits Settled Fine       | 79          | M 2   |
| 9.3      | SRI  | Surface Roughness Increased | 90          | S 1   |
| 9.3      | MGO  | General Observation         | 101         | NA    |
|          |      |                             |             |       |

Code:



| Description:      | <b>General Observation</b> |  |
|-------------------|----------------------------|--|
|                   |                            |  |
| Distance (ft):    | .0                         |  |
| Structural Grade: | 0                          |  |
| O&M Grade:        | 0                          |  |
| Clock Start/From: |                            |  |
| Clock To:         |                            |  |
| 1st Value:        |                            |  |
| 2nd Value:        |                            |  |
| Value Percent:    |                            |  |
| Step:             | NO                         |  |
| Remarks:          | access mh                  |  |

MGO



Code: SRI

Description: Surface Roughness Increased

Distance (ft): .0
Structural Grade: 1
O&M Grade: 0
Clock Start/From: 12
Clock To: 12

1st Value: 2nd Value: Value Percent:

Step: NO

Remarks:



Code: MGO

Description: General Observation

Distance (ft): 2.5
Structural Grade: 0
O&M Grade: 0
Clock Start/From:
Clock To:

1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: underside of frame



Code: IW

Description: Infil Weeper

Distance (ft): 8.1
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 2
Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks:



Code: **DSF** 

Description: Deposits Settled Fine

Distance (ft): 9.3
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 12
Clock To: 12

1st Value: 2nd Value:

Value Percent: 5.000 Step: NO

Remarks:



Code: SRI

Description: Surface Roughness Increased

Distance (ft): 9.3
Structural Grade: 1
O&M Grade: 0
Clock Start/From: 12
Clock To: 12
1st Value:
2nd Value:

Step: NO

Remarks:

Value Percent:



Code: MGO

Description: General Observation

Distance (ft): 9.3
Structural Grade: 0
O&M Grade: 0
Clock Start/From:
Clock To:
1st Value:

2nd Value: Value Percent:

Step: NO

Remarks: End Of Survey