

Manhole Inspection Report



Date:	09/28/2022	Weather:		Coding:	RZMACP
MH#:	M-305-026	Owner:	NA	Len. Surveyed:	9.2
P.O.#:		Surveyor:	Todd Machine	Rim to Invert:	10.0
Customer:		Cert. #:	P0038859-082022	Wall Material:	Concrete (cast in place)

Street:	North of Crows Nest Dr. 398' West o	Project:	Hobart, IN
City:	Hobart, IN	GPS Northing:	2288639.21
Location:	Yard	GPS Easting:	2896220.024
Drain Area:	West	GPS Accuracy:	Sub-Meter
Cover Shape:	Circular	Evidence of Surcharge:	No
Cover Size:	24.0	Potential for Runoff:	None
Comments:			


O&M Index:	2.00	O&M Quick:	2100	O&M Rating:	2.00
Structural Index:	1.20	Structural Quick:	3119	Structural Rating:	12.00
Overall Index:	1.27	Overall Quick:	3121	Overall Rating:	14.00

Position	Code	Observation	Video (sec)	Grade
<div> <div> <div>M-305-026</div> <div> <div>Camera Direction</div> <div></div> </div> </div> <div> <div></div> <div></div> </div> </div>				
.0	MGO	General Observation	10	NA
.0	SRI	Surface Roughness Increased	21	S 1
2.8	MGO	General Observation	40	NA
8.9	DSF	Deposits Settled Fine	66	M 2
8.9	SRI	Surface Roughness Increased	77	S 1
8.9	SAV	Surface Aggregate Visible	88	S 3
9.2	MGO	General Observation	100	NA




Code: **MGO**
Description: **General Observation**

Distance (ft): **.0**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From:
Clock To:
1st Value:
2nd Value:
Value Percent:
Step: **NO**
Remarks: **access mh**



Code: **SRI**
Description: **Surface Roughness Increased**

Distance (ft): **.0**
Structural Grade: **1**
O&M Grade: **0**
Clock Start/From: **12**
Clock To: **12**
1st Value:
2nd Value:
Value Percent:
Step: **NO**
Remarks:



Code: **MGO**
Description: **General Observation**


Distance (ft): **2.8**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From:
Clock To:
1st Value:
2nd Value:
Value Percent:
Step: **NO**
Remarks: **underside of frame**



Code: **DSF**
Description: **Deposits Settled Fine**


Distance (ft): **8.9**
Structural Grade: **0**
O&M Grade: **2**
Clock Start/From: **12**
Clock To: **12**
1st Value:
2nd Value:
Value Percent: **5.000**
Step: **NO**
Remarks:

Code:	SRI
Description:	Surface Roughness Increased



Distance (ft):	8.9
Structural Grade:	1
O&M Grade:	0
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	

Code:	SAV
Description:	Surface Aggregate Visible



Distance (ft):	8.9
Structural Grade:	3
O&M Grade:	0
Clock Start/From:	3
Clock To:	9
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	

Code:	MGO
Description:	General Observation



Distance (ft):	9.2
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	End Of Survey