
Date:	04/28/2018	Weather:		Coding:	RZMACP
MH#:	M-405-008	Owner:	NA	Len. Surveyed:	14.0
P.O.#:		Surveyor:	Jen Costello	Rim to Invert:	15.1
Customer:		Cert. #:	U-907-5518	Wall Material:	Concrete (reinforced)
Street:	Intersection of 3rd St. and Wabash S Project:			Hobart, IN	
City:	Hobart, IN		GPS Northing:	2898985.067	
Location:			GPS Easting:	2898985.067	
Drain Area:	West		GPS Accuracy:	Sub-Meter	
Cover Shape:	Circular		Evidence of Surcharge: No		
Cover Size: Comments:	22.5	Potential for Runo		None	
O&M Index:	2.00	O&M Quick:	2200	O&M Rating:	4.00
Structural Index:	0.00	Structural Qui	ck: 0000	Structural Rating:	0.00
Overall Index:	2.00	Overall Quick:	2200	Overall Rating:	4.00

Pos	ition Code	Observation	Video (sec)	Grade
405-008				
.0	MGO	General Observation	10	NA
2.3	MGO	General Observation	27	NA
/4.1	OBP	Obstacle External Pipe or Cable	44	M 2
/ 12.6	5 IW	Infil Weeper	73	M 2
14.0) MGO	General Observation	87	NA



Code: Description:	MGO General Observation
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	ACCESS MH



Code: MGO Description: **General Observation** Distance (ft): 2.3 Structural Grade: 0 0 O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Step: NO Remarks: UNDERSIDE OF FRAME



Distance (ft):	4.1
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	8
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	10.000
Step:	NO
Remarks:	

OBP

Obstacle External Pipe or Cable

Code:

Description:



IW
Infil Weeper
12.6
0
2
4
5
NO



Code: Description: MGO General Observation

Distance (ft):	14.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	END SURVEY