Date:	05/17/2018	Weather:		Coding:	RZMACP
MH#:	M-405-019	Owner:	NA	Len. Surveyed:	13.3
P.O.#:		Surveyor:	Jen Costello	Rim to Invert:	14.5
Customer:		Cert. #:	U-907-5518	Wall Material:	Concrete (reinforced)
Street:	LaSalle St. and 49th	n Ave. to the Nort	Project:	Hobart, IN	
City:	Hobart, IN		GPS Northing:	2898244.766	
Location:			GPS Easting:	2898244.766	
Drain Area:	West		GPS Accuracy:	Sub-Meter	
Cover Shape:	Circular		Evidence of Surcharge:	No	
Cover Size: Comments:	22.5	Potential for Runoff:		None	
O&M Index:	2.00	O&M Quick:	2100	O&M Rating:	2.00
Structural Index:	3.00	Structural Qu	ick: 3100	Structural Rating:	3.00
Overall Index:	2.50	Overall Quick		Overall Rating:	5.00

	Code	Observation	Video (sec)	Grade
405-019				
.0	MGO	General Observation	10	NA
1.7	MGO	General Observation	27	NA
5.6	SAP	Surface Aggregate Projecting	49	S 3
7.5	IW	Infil Weeper	64	M 2
13.3	MSA	Abandoned Survey	87	NA



Code:	MGO
Description:	General Observation
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	ACCESS MH



Code:	MGO
Description:	General Observation
Distance (ft):	1.7
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	UNDERSIDE OF FRAME

SAP

Surface Aggregate Projecting



Distance (ft):	5.6
Structural Grade:	3
O&M Grade:	0
Clock Start/From:	5
Clock To:	7
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	AROUND TAP

Code:

Description:



Code:	IW
Description:	Infil Weeper
Distance (ft):	7 5
Distance (ft):	7.5
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description: MSA Abandoned Survey

Distance (ft):	13.3
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	BENCH IS SUBMERGED