Manhole Inspection Report



Date: 05/14/2018 Weather: Coding: RZMACP

 MH#:
 M-504-058
 Owner:
 NA
 Len. Surveyed:
 7.7

 P.O.#:
 Surveyor:
 Jen Costello
 Rim to Invert:
 8.0

 Customer:
 Cert. #:
 U-907-5518
 Wall Material:
 Brick

Street: North of Home Ave. 162' West of Gu Project: Hobart, IN

City: Hobart, IN GPS Northing: 41.53910828

Location: GPS Easting: -87.27765656

Drain Area: West GPS Accuracy: Nearest Meter

Cover Shape: Circular Evidence of Surcharge: No
Cover Size: Potential for Runoff: None

Comments:

O&M Index:	2.00	O&M Quick:	2100	O&M Rating:	2.00
Structural Index:	0.00	Structural Quick:	0000	Structural Rating:	0.00
Overall Index:	2.00	Overall Quick:	2100	Overall Rating:	2.00

Wednesday, May 3, 2023

Position	Code	Observation	Video (sec)	Grade
M-504-058				
.0	MGO	General Observation	10	NA
1.8	MGO	General Observation	26	NA
6.5	DSZ	Deposits Settled Other	49	M 2
7.7	MGO	General Observation	63	NA
Camera Direction				



Description: Distance (ft): .0 Structural Grade: 0 O&M Grade: 0 Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Step: NO

MGO

General Observation

Remarks: **ACCESS MH**

Code:



Code: MGO

Description: General Observation

Distance (ft): 1.8
Structural Grade: 0
O&M Grade: 0
Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: UNDERSIDE OF FRAME



Code: DSZ

Description: Deposits Settled Other

Distance (ft): 6.5
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 12
Clock To: 12
1st Value:

2nd Value: Value Percent: Step:

Remarks: MISC



Code: MGO

Description: General Observation

10.000 NO

Distance (ft): 7.7
Structural Grade: 0
O&M Grade: 0
Clock Start/From:

Clock Start/Froi Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: END SURVEY

Wednesday, May 3, 2023