Manhole Inspection Report



Date: 05/14/2018 Weather: Coding: RZMACP

 MH#:
 M-504-080
 Owner:
 NA
 Len. Surveyed:
 9.5

 P.O.#:
 Surveyor:
 Jen Costello
 Rim to Invert:
 9.6

 Customer:
 Cert. #:
 U-907-5518
 Wall Material:
 Brick

Street: 172' East of California St. 414' South Project: Hobart, IN

City: Hobart, IN GPS Northing: 2901640.489

Location: GPS Easting: 2901640.489
Drain Area: Northwest GPS Accuracy: Sub-Meter


Cover Shape: Circular Evidence of Surcharge: No
Cover Size: Potential for Runoff: None

Comments:

O&M Index:	2.00	O&M Quick:	2100	O&M Rating:	2.00
Structural Index:	0.00	Structural Quick:	0000	Structural Rating:	0.00
Overall Index:	2.00	Overall Quick:	2100	Overall Rating:	2.00

Wednesday, May 3, 2023

Position	Code	Observation	Video (sec)	Grade
1-504-080				
.0	MGP	General Photo	10	NA
1.2	MGP	General Photo	26	NA
8.5	RFB	Roots Fine Barrel	54	M 2
9.5	MGO	General Observation	68	NA
Camera Direction				



Description: **General Photo** Distance (ft): .0 Structural Grade: 0 O&M Grade: 0 Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Step: NO Remarks: **ACCESS MH**

MGP

Wednesday, May 3, 2023 2

Code:



Code: MGP

Description: General Photo

Distance (ft): 1.2
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: **uNDERSIDE OF FRAME**



Code: RFB

Description: Roots Fine Barrel

Distance (ft): 8.5
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 9
Clock To: 11
1st Value:

2nd Value: Value Percent:

Step: NO

Remarks:





Distance (ft): 9.5
Structural Grade: 0

O&M Grade: 0

Clock Start/From: Clock To:

1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: END SURVEY

Wednesday, May 3, 2023