## **Manhole Inspection Report**



Date:

Customer:

05/14/2018

Weather:

Coding:

**RZMACP** 

MH#:

M-504-083

Owner: NA

Len. Surveyed: 8.7 Rim to Invert:

P.O.#:

Surveyor:

Cert. #:

Jen Costello U-907-5518

Wall Material:

Concrete (reinforced)

Street: City:

161' East of California St. 311' North Project:

Hobart, IN

Hobart, IN

**GPS Northing:** 

2901622.799

Location:

GPS Easting:

2901622.799

Drain Area: Cover Shape: Northwest

GPS Accuracy:

Sub-Meter

Cover Size:

Circular

22.5

Evidence of Surcharge: No

Potential for Runoff: None

Comments:

O&M Index:

2.00 2.00

O&M Quick: Structural Quick:

2100

2100

O&M Rating: Structural Rating:

2.00 2.00

4.00

Structural Index: Overall Index:

2.00 Overall Quick:


2200 Overall Rating:

Wednesday, May 3, 2023

1

	Position	Code	Observation	Video (sec)	Grade
M-504-08	3				
	.0	MGP	General Photo	10	NA
- 11	1.2	SSS	Surface Spalling	24	S 2
	8.7	DSF	Deposits Settled Fine	51	M 2
	8.7	MGO	General Observation	62	NA
Camera Direction					


Code:



Description:	General Photo
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent:	
Step:	NO
Remarks:	access MH

MGP

Wednesday, May 3, 2023



Code: SSS

Description: Surface Spalling

Distance (ft): 1.2
Structural Grade: 2
O&M Grade: 0
Clock Start/From: 6

Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks:



Code: **DSF** 

Description: Deposits Settled Fine

Distance (ft): 8.7
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 12
Clock To: 12
1st Value:

2nd Value:
Value Percent: 5.000
Step: NO

Remarks:



Code: MGO

Description: General Observation

Distance (ft): 8.7
Structural Grade: 0
O&M Grade: 0
Clock Start/From:

Clock Start/From Clock To:
1st Value:
2nd Value:
Value Percent:

Step: NO

Remarks: END SURVEY

Wednesday, May 3, 2023