Date:	05/15/2018	Weather:		Coding:	RZMACP
MH#:	M-504-105	Owner:	NA	Len. Surveyed:	8.0
P.O.#:		Surveyor:	Jen Costello	Rim to Invert:	8.4
Customer:		Cert. #:	U-907-5518	Wall Material:	Concrete (reinforced)
Street:	116' West of Virgir	nia St. 335' South	Project:	Hobart, IN	
City:	Hobart, IN		GPS Northing:	41.54178238	
Location:			GPS Easting:	-87.27225494	
Drain Area:	Northwest		GPS Accuracy:	Nearest Meter	
Cover Shape:	Circular		Evidence of Surcharge:	No	
Cover Size: Comments:	22.5		Potential for Runoff:	None	
O&M Index:	2.00	O&M Quick:	2100	O&M Rating:	2.00
Structural Index:	3.00	Structural Qu	uick: 3100	Structural Rating:	3.00
Overall Index:	2.50	Overall Quic	k: <b>3121</b>	Overall Rating:	5.00

	Code	Observation	Video (sec)	Grade
504-105				
.0	MGO	General Observation	10	NA
1.3	FS	Fracture Spiral	25	S 3
/2.4	MGO	General Observation	41	NA
6.7	DSF	Deposits Settled Fine	63	M 2
7.9	MGO	General Observation	77	NA



MGO General Observation
.0
0
0
NO
ACCESS MH



Code:	FS
Description:	Fracture Spiral
Distance (ft):	1.3
Structural Grade:	3
O&M Grade:	0
Clock Start/From:	12
Clock To:	1
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description:	MGO General Observation
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Step: Remarks:	2.4 0 0 VNO
Remarks:	UNDERSIDE OF FRAME



Code: Description:	DSF Deposits Settled Fine
Distance (ft):	6.7
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	5.000
Step:	NO
Remarks:	



Code:MGODescription:General Observation

Distance (ft):	7.9
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	END SURVEY