Date:	05/14/2018	Weather:		Coding:	RZMACP
MH#:	M-504-134	Owner:	NA	Len. Surveyed:	4.7
P.O.#:		Surveyor:	Jen Costello	Rim to Invert:	5.5
Customer:		Cert. #:	U-907-5518	Wall Material:	Concrete (reinforced)
Street:	43rd Pl. and 191' E	ast of Cavender St	Project:	Hobart, IN	
City:	Hobart, IN		GPS Northing:	41.53867722	
Location:			GPS Easting:	-87.27183533	
Drain Area:	West		GPS Accuracy:	Nearest Meter	
Cover Shape:	Circular		Evidence of Surcharge:	No	
Cover Size: Comments:	22.5		Potential for Runoff:	None	
O&M Index:	2.00	O&M Quick:	2300	O&M Rating:	6.00
Structural Index:	0.00	Structural Qui	ck: 0000	Structural Rating:	0.00
Overall Index:	2.00	Overall Quick	2300	Overall Rating:	6.00

Observation10eper21Observation32n43Observation60a Attached Encrustation73a Settled Fine87Observation102	NA M 2 NA NA M 2 M 2 NA
eper21Observation32n43Observation60a Attached Encrustation73a Settled Fine87	M 2 NA NA NA M 2 M 2
Observation32n43Observation60G Attached Encrustation73G Settled Fine87	NA NA NA M 2 M 2
n 43 Observation 60 S Attached Encrustation 73 S Settled Fine 87	NA NA M 2 M 2
Observation60S Attached Encrustation73S Settled Fine87	NA M 2 M 2
Attached Encrustation73Settled Fine87	M 2 M 2
Settled Fine 87	M 2
Observation 102	NA




Code: Description:	MGO General Observation
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	ACCESS MH



Code:	IW
Description:	Infil Weeper
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description:	MGO General Observation
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Step: Remarks:	.0 0 0 NO ACCESS MH
nemarks.	



Code: Description:	IS Infil Stain
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: M Description: G

Code:

Description:

MGO General Observation

Distance (ft):	1.5
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	UNDERSIDE OF FRAME

DAE

Deposits Attached Encrustation



Distance (ft):	1.5
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	5.000
Step:	NO
Remarks:	



Code:	DSF
Description:	Deposits Settled Fine
Distance (ft):	3.1
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	5.000
Step:	NO
Remarks:	



Code:MGODescription:General Observation

Distance (ft):	4.7
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	END SURVEY