Manhole Inspection Report



Date: 04/28/2018 Weather: Coding: RZMACP

MH#: M-505-082 Owner: NA Len. Surveyed: 8.6
P.O.#: Surveyor: Jen Costello Rim to Invert: 9.1

Customer: Cert. #: U-907-5518 Wall Material: Concrete

(reinforced)

Street: 4th St. 564' East of Wabash St. Project: Hobart, IN
City: Hobart, IN GPS Northing: 2899645.963

Location: GPS Easting: **2899645.963**Drain Area: West GPS Accuracy: Sub-Meter

Cover Shape: Circular Evidence of Surcharge: No
Cover Size: Potential for Runoff: None

Comments:

2.00 2200 4.00 O&M Index: O&M Quick: O&M Rating: 0.00 0000 0.00 Structural Index: Structural Quick: Structural Rating: 2.00 2200 4.00 Overall Index: Overall Quick: Overall Rating:

Wednesday, May 3, 2023

Pc	osition Code	Observation	Video (sec)	Grade
M-505-082				
.0	MGO	General Observation	10	NA
0.	DAE	Deposits Attached Encrustation	21	M 2
1.4	4 MGP	General Photo	37	NA
$\sqrt{3.2}$	2 OBP	Obstacle External Pipe or Cable	53	M 2
8.5	5 MGO	General Observation	74	NA
Camera Direction				



Code: MGO Description: **General Observation**

Distance (ft): .0 Structural Grade: 0 O&M Grade: 0 Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Step:

NO

Remarks: **ACCESS MH**



Code: DAE

Description: Deposits Attached Encrustation

Distance (ft): .0
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 12
Clock To: 12

1st Value: 2nd Value:

Value Percent: 5.000 Step: NO

Remarks:



Code: MGP

Description: General Photo

Distance (ft): 1.4
Structural Grade: 0
O&M Grade: 0
Clock Start/From:
Clock To:

1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: UNDERSIDE OF FRAME



Code: OBP

Description: Obstacle External Pipe or Cable

Distance (ft): 3.2
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 10
Clock To:

1st Value: 2nd Value:

Value Percent: 10.000
Step: NO

Remarks:

Wednesday, May 3, 2023 3



Code: MGO

Description: General Observation

Distance (ft): 8.5
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: END SURVEY

4