Manhole Ins	spection Repor	t			
Date:	09/28/2022	Weather:		Coding:	RZMACP
MH#:	M-506-005	Owner:	NA	Len. Surveyed:	15.3
P.O.#:		Surveyor:	Jen Costello	Rim to Invert:	16.9
Customer:		Cert. #:	U-907-5518	Wall Material:	Concrete (cast ir place)
Street:	8th St. 277' East of	Colorado St.	Project:	Hobart, IN	
City:	Hobart, IN		GPS Northing:	2286508.681	
Location:	Yard		GPS Easting:	2900815.372	
Drain Area:	Southwest		GPS Accuracy:	Sub-Meter	
Cover Shape:	Circular		Evidence of Surcharge:	No	
Cover Size: Comments:	24.0		Potential for Runoff:	None	
O&M Index:	2.00	O&M Quick:	2200	O&M Rating:	4.00
Structural Index:	1.00	Structural Qu	ick: 1800	Structural Rating:	16.00
Overall Index:	1.11	Overall Quick		Overall Rating:	20.00

	Position	Code	Observation	Video (sec)	Grade
<b>506-00</b>	)5				
Ÿ	.0	MGO	General Observation	10	NA
	.0	SRI	Surface Roughness Increased	22	S 1
ш.	2.1	MGO	General Observation	39	NA
	3.9	IW	Infil Weeper	56	M 2
ш.	/15.3	DSGV	Deposits Settled Gravel	89	M 2
	15.3	SRI	Surface Roughness Increased	100	S 1
	15.3	SRI	Surface Roughness Increased	111	S 1
ш.	15.3	MGO	General Observation	122	NA
1					



Code: Description:	MGO General Observation
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	access mh



Code:SRIDescription:Surface Roughness Increased

Distance (ft):	.0
Structural Grade:	1
O&M Grade:	0
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description:	MGO General Observation
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Step:	2.1 0 0
Remarks:	underside of frame



Code: Description:	IW Infil Weeper
Distance (ft):	3.9
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	6
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description: **Deposits Settled Gravel** Distance (ft): 15.3 Structural Grade: 0 O&M Grade: 2 Clock Start/From: 12 Clock To: 12 1st Value: 2nd Value: Value Percent: 5.000 Step: NO Remarks:

Code:

DSGV



Description:	Surface Roughness Increased
Distance (ft):	15.3
Structural Grade:	1
O&M Grade:	0
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	

SRI



Code: Description:	SRI Surface Roughness Increased
Distance (ft):	15.3
Structural Grade:	1
O&M Grade:	0
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code:MGODescription:General Observation

Distance (ft):	15.3
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	end of survey