Date:	09/25/2022	Weather:		Coding:	RZMACP
MH#:	M-507-096	Owner:	NA	Len. Surveyed:	4.3
P.O.#:		Surveyor:	Jen Costello	Rim to Invert:	5.2
Customer:		Cert. #:	U-907-5518	Wall Material:	Concrete (cast ir place)
Street:	167' Southwest of 10	th St. and Deca	Project:	Hobart, IN	
City:	Hobart, IN		GPS Northing:	2285132.837	
Location:	Local Rural Streets		GPS Easting:	2899964.751	
Drain Area:	Southwest		GPS Accuracy:	Sub-Meter	
Cover Shape:	Circular		Evidence of Surcharge:	No	
Cover Size: Comments:	24.0		Potential for Runoff:	None	
O&M Index:	2.00	O&M Quick:	2100	O&M Rating:	2.00
Structural Index:	1.00	Structural Qu	uick: 1400	Structural Rating:	4.00
Overall Index:	1.20	Overall Quicl	k: 2114	Overall Rating:	6.00

Position	Code	Observation	Video (sec)	Grade
07-096				
.0	MGO	General Observation	10	NA
.0	SRI	Surface Roughness Increased	21	S 1
4.3	DSF	Deposits Settled Fine	41	M 2
4.3	SRI	Surface Roughness Increased	53	S 1
4.3	MGO	General Observation	64	NA



Code: Description:	MGO General Observation
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	access mh



Code:SRIDescription:Surface Roughness Increased

Distance (ft):	.0
Structural Grade:	1
O&M Grade:	0
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description:	DSF Deposits Settled Fine
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Step: Remarks:	4.3 0 2 12 12 5.000 NO



Code: Description:	SRI Surface Roughness Increased
Distance (ft):	4.3
Structural Grade:	1
O&M Grade:	0
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description: MGO General Observation

Distance (ft):	4.3
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	end of survey