Date:	04/29/2018	Weather:		Coding:	RZMACP
MH#:	M-604-006	Owner:	NA	Len. Surveyed:	9.1
P.O.#:		Surveyor:	Jen Costello	Rim to Invert:	9.2
Customer:		Cert. #:	U-907-5518	Wall Material:	Concrete (reinforced)
Street:	Intersection of Bev	erly Blvd. and Cle	Project:	Hobart, IN	
City:	Hobart, IN		GPS Northing:	2903570.095	
Location:			GPS Easting:	2903570.095	
Drain Area:	West		GPS Accuracy:	Sub-Meter	
Cover Shape:	Circular		Evidence of Surcharge:	No	
Cover Size: Comments:	22.5		Potential for Runoff:	None	
O&M Index:	0.00	O&M Quick:	0000	O&M Rating:	0.00
Structural Index:	3.50	Structural Qui	ck: 4131	Structural Rating:	7.00
Overall Index:	3.50	Overall Quick		Overall Rating:	7.00

	Position	Code	Observation	Video (sec)	Grade
M-604-00)6				
\sim	.0	MGO	General Observation	10	NA
	.0	СМ	Crack Multiple	21	S 3
	1.6	MGP	General Photo	37	NA
	/ 1.9	FM	Fracture Multiple	50	S 4
	9.1	MGO	General Observation	76	NA
Camera Direction					



Code: Description:	MGO General Observation
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	ACCESS MH



Code:	СМ
Description:	Crack Multiple
Distance (ft):	.0
Structural Grade:	3
O&M Grade:	0
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description:	MGP General Photo
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Step: Remarks:	1.6 0 0 NO UNDERSIDE OF FRAME



Code: Description:	FM Fracture Multiple
Distance (ft):	1.9
Structural Grade:	4
O&M Grade:	0
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description:

MGO General Observation

Distance (ft):	9.1
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	END SURVEY