Manhole Inspection Report



Date: **04/29/2018** Weather: Coding:

MH#: M-604-060 Owner: NA Len. Surveyed: 5.6
P.O.#: Surveyor: Jen Costello Rim to Invert: 5.9

Customer: Cert. #: U-907-5518 Wall Material: Concrete

(reinforced)

RZMACP

Street: Connecticut St. 210' North of Clevel Project: Hobart, IN

City: Hobart, IN GPS Northing: 2902808.66

Location: GPS Easting: 2902808.66
Drain Area: West GPS Accuracy: Sub-Meter

Cover Shape: Circular Evidence of Surcharge: No
Cover Size: Potential for Runoff: None

Comments:

2.00 2100 2.00 O&M Index: O&M Quick: O&M Rating: 3100 3.00 3.00 Structural Index: Structural Quick: Structural Rating: 2.50 3121 5.00 Overall Index: Overall Quick: Overall Rating:

Wednesday, May 3, 2023

	Code	Observation	Video (sec)	Grade
604-060				
.0	MGO	General Observation	10	NA
1.4	MGP	General Photo	26	NA
3.0	DSF	Deposits Settled Fine	43	M 2
3.0	SAV	Surface Aggregate Visible	55	S 3
5.1	MGO	General Observation	71	NA




Description: Distance (ft): .0 Structural Grade: 0 O&M Grade: 0 Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Step: NO

MGO

General Observation

Remarks: **ACCESS MH**

Code:



Code: MGP

Description: General Photo

Distance (ft): 1.4
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: UNDERSIDE OF FRAME



Code: **DSF**

Description: Deposits Settled Fine

Distance (ft): 3.0
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 12
Clock To: 12
1st Value:

2nd Value:

Value Percent: 5.000 Step: NO

Remarks:

Code: SAV

Description: Surface Aggregate Visible

12



Distance (ft): 3.0 Structural Grade: 3

O&M Grade: 0
Clock Start/From: 12

Clock To: 1st Value: 2nd Value:

Value Percent:

Step: NO

Remarks:

Wednesday, May 3, 2023



Code: MGO

Description: General Observation

Distance (ft): 5.1
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: END SURVEY

4