Manhole Inspection Report



Date: 04/29/2018 Weather: Coding: RZMACP

MH#:M-604-108Owner:NALen. Surveyed:4.3P.O.#:Surveyor:Jen CostelloRim to Invert:4.5Customer:Cert. #:U-907-5518Wall Material:Brick

Street: Ash St. 352' South of Home Ave. Project: Hobart, IN
City: Hobart, IN GPS Northing: 2903134.757

Location: GPS Easting: **2903134.757**

Drain Area: West GPS Accuracy: Sub-Meter
Cover Shape: Circular Evidence of Surcharge: No

Cover Shape: Circular Evidence of Surcharge: No
Cover Size: Potential for Runoff: None

Comments:

O&M Index:	2.00	O&M Quick:	2200	O&M Rating:	4.00
Structural Index:	0.00	Structural Quick:	0000	Structural Rating:	0.00
Overall Index:	2.00	Overall Quick:	2200	Overall Rating:	4.00

Wednesday, May 3, 2023

	Position	Code	Observation	Video (sec)	Grade
M-604-10)8				
	0	MGO	General Observation	10	NA
- 11	1.1	RFB	Roots Fine Barrel	22	M 2
- 11	1.4	MGP	General Photo	36	NA
- 11	3.3	DSF	Deposits Settled Fine	53	M 2
- 1117	4.3	MGO	General Observation	66	NA
Camera Direction					

Code:



Description: **General Observation** Distance (ft): .0 Structural Grade: 0 O&M Grade: 0 Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Step: NO Remarks: **ACCESS MH**

MGO

Wednesday, May 3, 2023 2



Code: RFB

Description: Roots Fine Barrel

Distance (ft): 1.1
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 12
Clock To: 12

1st Value: 2nd Value: Value Percent:

Step: NO

Remarks:



Code: MGP

Description: General Photo

Distance (ft): 1.4
Structural Grade: 0

O&M Grade: 0

Clock Start/From:
Clock To:

1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: UNDERSIDE OF FRAME



Code: **DSF**

Description: Deposits Settled Fine

Distance (ft): 3.3
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 12
Clock To: 12

1st Value: 2nd Value:

Value Percent: 10.000 Step: NO

Remarks:

Wednesday, May 3, 2023



Code: MGO

Description: General Observation

Distance (ft): 4.3
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: END SURVEY

4