Date:	04/26/2018	Weather:		Coding:	RZMACP
MH#:	M-606-003	Owner:	NA	Len. Surveyed:	11.6
P.O.#:		Surveyor:	Jen Costello	Rim to Invert:	12.1
Customer:		Cert. #:	U-907-5518	Wall Material:	Concrete (reinforced)
Street:	Lake Park Ave. 523' North of 10th St. Project: Hobart, IN				
City:	Hobart, IN	(GPS Northing:	2904528.778	
Location:		(GPS Easting:	2904528.778	
Drain Area:	Southeast	(GPS Accuracy:	Sub-Meter	
Cover Shape:	Circular	E	Evidence of Surcharge:	No	
Cover Size: Comments:	22.5	I	Potential for Runoff:	None	
O&M Index:	2.00	O&M Quick:	2100	O&M Rating:	2.00
Structural Index:	2.00	Structural Quid	ck: 2100	Structural Rating:	2.00
Overall Index:	2.00	Overall Quick:	2200	Overall Rating:	4.00

	Code	Observation	Video (sec)	Grade
6-003				
.0	MGO	General Observation	10	NA
.8	FC	Fracture Circumferential	23	S 2
2.0	MGO	General Observation	39	NA
9.1	IW	Infil Weeper	67	M 2
11.6	MGO	General Observation	83	NA




Code: Description:	MGO General Observation
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	ACCESS MH



Code:FCDescription:Fracture Circumferential

Distance (ft):	.8
Structural Grade:	2
O&M Grade:	0
Clock Start/From:	8
Clock To:	9
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description:	MGO General Observation
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To:	2.0 0 0
1st Value: 2nd Value:	
Value Percent: Step:	NO
Remarks:	UNDERSIDE OF FRAME



Code: Description:	IW Infil Weeper
Distance (ft):	9.1
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	5
Clock To:	7
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description: MGO General Observation

Distance (ft):	11.6
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	END SURVEY