Date:	04/26/2018	Weather:		Coding:	RZMACP
MH#:	M-606-015	Owner:	NA	Len. Surveyed:	11.1
P.O.#:		Surveyor:	Jen Costello	Rim to Invert:	12.1
Customer:		Cert. #:	U-907-5518	Wall Material:	Concrete (reinforced)
Street:	8th Pl. 155' East of	f Ash St.	Project:	Hobart, IN	
City:	Hobart, IN		GPS Northing:	0.0	
Location:			GPS Easting:	0.0	
Drain Area:	Southwest		GPS Accuracy:	Nearest Meter	
Cover Shape:	Circular		Evidence of Surcharge:	No	
Cover Size: Comments:	22.5		Potential for Runoff:	None	
O&M Index:	2.00	O&M Quick:	2300	O&M Rating:	6.00
Structural Index:	0.00	Structural Qui	ck: 0000	Structural Rating:	0.00
Overall Index:	2.00	Overall Quick	2300	Overall Rating:	6.00

Position	Code	Observation	Video (sec)	Grade
1-606-015				
.0	MGO	General Observation	10	NA
2.3	IW	Infil Weeper	26	M 2
/8.1	IW	Infil Weeper	50	M 2
/ 10.9	DSF	Deposits Settled Fine	68	M 2
11.1	MGO	General Observation	80	NA
Camera Direction				



Code: Description:	MGO General Observation
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	ACCESS MH



Code:	IW
Description:	Infil Weeper
Distance (ft):	2.3
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code:	IW
Description:	Infil Weeper
Distance (ft):	8.1
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	10
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code:	DSF
Description:	Deposits Settled Fine
Distance (ft):	10.9
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	5.000
Step:	NO
Remarks:	



Code: Mo Description: Ge

MGO General Observation

Distance (ft):	11.1
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	END SURVEY

Wednesday, May 3, 2023