Date:	04/26/2018	Weather:		Coding:	RZMACP
MH#:	M-606-073	Owner:	NA	Len. Surveyed:	7.9
P.O.#:		Surveyor:	Jen Costello	Rim to Invert:	8.6
Customer:		Cert. #:	U-907-5518	Wall Material:	Concrete (reinforced)
Street:	74' South of 7th St	. East of Wisconsi	Project:	Hobart, IN	
City:	Hobart, IN		GPS Northing:	41.52706909	
Location:			GPS Easting:	-87.26847839	
Drain Area:	Southwest		GPS Accuracy:	Nearest Meter	
Cover Shape:	Circular		Evidence of Surcharge:	No	
Cover Size: Comments:	22.5		Potential for Runoff:	None	
O&M Index:	2.00	O&M Quick:	2700	O&M Rating:	14.00
Structural Index:	0.00	Structural Qui	ck: 0000	Structural Rating:	0.00
Overall Index:	2.00	Overall Quick:	2700	Overall Rating:	14.00

\frown	Code	Observation	Video (sec)	Grade
606-073				
.0	MGO	General Observation	10	NA
1.3	MGO	General Observation	26	NA
/1.3	DAE	Deposits Attached Encrustation	38	M 2
2.9	IS	Infil Stain	52	NA
7.9	DAE	Deposits Attached Encrustation	73	M 2
7.9	MGO	General Observation	83	NA



Code: Description:	MGO General Observation
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	ACCESS MH



Code:	MGO
Description:	General Observation
Distance (ft):	1.3
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	UNDERSIDE OF FRAME

DAE

NO



Description:	Deposits Attached Encrustation
Distance (ft):	1.3
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	5.000

Code:

Step: Remarks:



Code: Description:	IS Infil Stain
Distance (ft):	2.9
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code:DAEDescription:Deposits Attached Encrustation

Distance (ft):	7.9
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	5.000
Step:	NO
Remarks:	



MGO General Observation
7.9
0
0
NO
END SURVEY