Manhole Inspection Report



Date:

04/26/2018

Weather:

Coding:

RZMACP

MH#:

M-606-087

Owner: NA Len. Surveyed:

P.O.#:

Surveyor: Jen Costello U-907-5518 Cert. #:

Rim to Invert:

16.5 Wall Material: Concrete

(reinforced)

15.2

Street:

Customer:

Lake Shore Dr. Sunset St. to the Wes Project:

Hobart, IN

City:

GPS Northing:

2902411.998

Location:

GPS Easting:

2902411.998

Drain Area:

GPS Accuracy:

Sub-Meter

Cover Shape:

Southwest Circular

Hobart, IN

Evidence of Surcharge: No

Cover Size:

22.5

Potential for Runoff: None

Comments:

O&M Index:

2.00 0.00 O&M Quick:

2100 0000

O&M Rating: Structural Rating:

2.00 0.00

2.00

Structural Index: Overall Index:

Structural Quick: 2.00 Overall Quick:

2100 Overall Rating:

Wednesday, May 3, 2023

1

	Position	Code	Observation	Video (sec)	Grade
M-606-08	7				
	.0	MGO	General Observation	10	NA
-11	11.7	IW	Infil Weeper	44	M 2
-11	15.2	MGO	General Observation	62	NA
Camera Direction					



Code: MGO

Description: General Observation

Distance (ft): .0
Structural Grade: 0
O&M Grade: 0
Clock Start/From:
Clock To:
1st Value:
2nd Value:

Step: NO

Value Percent:

Remarks: ACCESS MH



Code: IW

Description: Infil Weeper

Distance (ft): 11.7
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 9
Clock To: 3
1st Value:

1st Value: 2nd Value: Value Percent:

Step: NO

Remarks:



Code: MGO

Description: General Observation

Distance (ft): 15.2
Structural Grade: 0
O&M Grade: 0
Clock Start/From:

Clock To:
1st Value:
2nd Value:
Value Percent:

Step: NO

Remarks: END SURVEY

Wednesday, May 3, 2023