

Manhole Inspection Report



Date:	04/26/2018	Weather:		Coding:	RZMACP
MH#:	M-606-088	Owner:	NA	Len. Surveyed:	13.9
P.O.#:		Surveyor:	Jen Costello	Rim to Invert:	14.5
Customer:		Cert. #:	U-907-5518	Wall Material:	Concrete (reinforced)

Street:	Intersection of Glendale and Lake Sh	Project:	Hobart, IN
City:	Hobart, IN	GPS Northing:	2902215.037
Location:		GPS Easting:	2902215.037
Drain Area:	Southwest	GPS Accuracy:	Sub-Meter
Cover Shape:	Circular	Evidence of Surcharge:	No
Cover Size:	22.5	Potential for Runoff:	None
Comments:			

O&M Index:	0.00	O&M Quick:	0000	O&M Rating:	0.00
Structural Index:	5.00	Structural Quick:	5200	Structural Rating:	10.00
Overall Index:	5.00	Overall Quick:	5200	Overall Rating:	10.00

	Position	Code	Observation	Video (sec)	Grade
<p>M-606-088</p> <p>Camera Direction</p>	.0	MGO	General Observation	10	NA
	.0	B	Broken	21	S 5
	1.5	MGO	General Observation	38	NA
	1.5	SRV	Surface Reinforcement Visible	50	S 5
	7.7	IS	Infil Stain	74	NA
	13.9	MGO	General Observation	97	NA



Code: **MGO**

Description: **General Observation**

Distance (ft): **.0**

Structural Grade: **0**

O&M Grade: **0**

Clock Start/From:

Clock To:

1st Value:

2nd Value:

Value Percent:


Step: **NO**

Remarks: **ACCESS MH**



Code: **B**
Description: **Broken**

Distance (ft): **.0**
Structural Grade: **5**
O&M Grade: **0**
Clock Start/From: **7**
Clock To: **11**
1st Value:
2nd Value:
Value Percent:
Step: **NO**
Remarks:



Code: **MGO**
Description: **General Observation**

Distance (ft): **1.5**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From:
Clock To:
1st Value:
2nd Value:
Value Percent:
Step: **NO**
Remarks: **UNDERSIDE OF FRAME**



Code: **SRV**
Description: **Surface Reinforcement Visible**

Distance (ft): **1.5**
Structural Grade: **5**
O&M Grade: **0**
Clock Start/From: **12**
Clock To: **12**
1st Value:
2nd Value:
Value Percent:
Step: **NO**
Remarks:



Code: **IS**
Description: **Infil Stain**

Distance (ft): **7.7**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From: **12**
Clock To: **12**
1st Value:
2nd Value:
Value Percent:
Step: **NO**
Remarks:



Code: **MGO**
Description: **General Observation**

Distance (ft): **13.9**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From:
Clock To:
1st Value:
2nd Value:
Value Percent:
Step: **NO**
Remarks: **END SURVEY**