

# Manhole Inspection Report



Date:	<b>10/26/2022</b>	Weather:		Coding:	<b>RZMACP</b>
MH#:	<b>M-703-033</b>	Owner:	<b>NA</b>	Len. Surveyed:	<b>11.3</b>
P.O.#:		Surveyor:	<b>Jen Costello</b>	Rim to Invert:	<b>12.5</b>
Customer:		Cert. #:	<b>U-907-5518</b>	Wall Material:	<b>Concrete (cast in place)</b>

Street:	<b>Intersection of Hidden Lake Dr. and</b>	Project:	<b>Hobart, IN</b>
City:	<b>Hobart, IN</b>	GPS Northing:	<b>2293589.546</b>
Location:	<b>Other</b>	GPS Easting:	<b>2905034.205</b>
Drain Area:	<b>North</b>	GPS Accuracy:	<b>Sub-Meter</b>
Cover Shape:	<b>Circular</b>	Evidence of Surcharge:	<b>Yes</b>
Cover Size:	<b>24.0</b>	Potential for Runoff:	<b>None</b>
Comments:			

O&M Index:	<b>2.00</b>	O&M Quick:	<b>2100</b>	O&M Rating:	<b>2.00</b>
Structural Index:	<b>1.00</b>	Structural Quick:	<b>1A00</b>	Structural Rating:	<b>11.00</b>
Overall Index:	<b>1.08</b>	Overall Quick:	<b>211A</b>	Overall Rating:	<b>13.00</b>

**Camera Direction**

**M-703-033**

Position	Code	Observation	Video (sec)	Grade
.0	MGO	General Observation	10	NA
.0	SRI	Surface Roughness Increased	21	S 1
1.4	MGO	General Observation	38	NA
11.3	DSF	Deposits Settled Fine	71	M 2
11.3	SRI	Surface Roughness Increased	82	S 1
11.3	MGO	General Observation	94	NA



Code:	MGO
Description:	General Observation


Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	ac



Code: **SRI**  
Description: **Surface Roughness Increased**

Distance (ft): **.0**  
Structural Grade: **1**  
O&M Grade: **0**  
Clock Start/From: **12**  
Clock To: **12**  
1st Value:  
2nd Value:  
Value Percent:  
Step: **NO**  
Remarks:


---



Code: **MGO**  
Description: **General Observation**


Distance (ft): **1.4**  
Structural Grade: **0**  
O&M Grade: **0**  
Clock Start/From:  
Clock To:  
1st Value:  
2nd Value:  
Value Percent:  
Step: **NO**  
Remarks: **underside of frame**

---




Code: **DSF**  
Description: **Deposits Settled Fine**

Distance (ft): **11.3**  
Structural Grade: **0**  
O&M Grade: **2**  
Clock Start/From: **12**  
Clock To: **12**  
1st Value:  
2nd Value:  
Value Percent: **5.000**  
Step: **NO**  
Remarks:



Code: **SRI**  
Description: **Surface Roughness Increased**

Distance (ft): **11.3**  
Structural Grade: **1**  
O&M Grade: **0**  
Clock Start/From: **12**  
Clock To: **12**  
1st Value:  
2nd Value:  
Value Percent:  
Step: **NO**  
Remarks:



Code: **MGO**  
Description: **General Observation**

Distance (ft): **11.3**  
Structural Grade: **0**  
O&M Grade: **0**  
Clock Start/From:  
Clock To:  
1st Value:  
2nd Value:  
Value Percent:  
Step: **NO**  
Remarks: **end of survey**