Manhole Inspection Report



04/19/2018 Date: Weather:

M-708-103 MH#: Owner: NA Len. Surveyed: 8.2 P.O.#: John Kuglmaier 8.9 Surveyor: Rim to Invert:

U-1215-07002349 Customer: Cert. #: Wall Material: **Concrete**

Project:

(reinforced)

RZMACP

Coding:

Hobart, IN

2905382.854

Street: Bracken Parkway. 710' East of Lake

Hobart, IN **GPS Northing:** 2905382.854

City: Location: GPS Easting:

Drain Area: Southwest GPS Accuracy: **Sub-Meter**

Cover Shape: Circular Evidence of Surcharge: No Cover Size: 22.5 Potential for Runoff: None

Comments:

2.00 2100 2.00 O&M Index: O&M Quick: O&M Rating: 0.00 0000 0.00 Structural Index: Structural Quick: Structural Rating: 2.00 2100 2.00 Overall Index: Overall Quick: Overall Rating:

Wednesday, May 3, 2023 1

Position	Code	Observation	Video (sec)	Grade
08-103				
.0	MGP	General Photo	10	NA
2.7	MGP	General Photo	29	NA
5.3	DSF	Deposits Settled Fine	48	M 2
6.1	IS	Infil Stain	61	NA
6.1	IS	Infil Stain	73	NA
7.1	MGO	General Observation	87	NA

Code:



Description:	General Photo
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	

MGP

Wednesday, May 3, 2023



Code: MGP

Description: General Photo

Distance (ft): 2.7
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock Start/From: Clock To:

1st Value: 2nd Value: Value Percent:

Step: NO

Remarks:



Code: **DSF**

Description: Deposits Settled Fine

Distance (ft): 5.3
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 6
Clock To: 12
1st Value:

1st Value: 2nd Value:

Value Percent: 5.000 Step: NO

Remarks:

Code:

Description: Infil Stain

IS



Distance (ft): 6.1

Structural Grade: 0

O&M Grade: 0

Clock Start/From: 4

Clock To: 1st Value:

2nd Value: Value Percent:

Step: NO

Remarks:

Wednesday, May 3, 2023 3



Code: IS

Description: Infil Stain

Distance (ft): 6.1
Structural Grade: 0

O&M Grade: 0

Clock Start/From: 10

Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks:



Code: MGO

Description: General Observation

Distance (ft): 7.1
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: Ins. Comp.