

# Manhole Inspection Report



Date:	<b>04/19/2018</b>	Weather:		Coding:	<b>RZMACP</b>
MH#:	<b>M-708-198</b>	Owner:	<b>NA</b>	Len. Surveyed:	<b>5.9</b>
P.O.#:		Surveyor:	<b>John Kuglmaier</b>	Rim to Invert:	<b>6.5</b>
Customer:		Cert. #:	<b>U-1215-07002349</b>	Wall Material:	<b>Concrete (reinforced)</b>

Street:	<b>644' East of 14th St. and Hwy 51.</b>	Project:	<b>Hobart, IN</b>
City:	<b>Hobart, IN</b>	GPS Northing:	<b>2905302.263</b>
Location:		GPS Easting:	<b>2905302.263</b>
Drain Area:	<b>Southwest</b>	GPS Accuracy:	<b>Sub-Meter</b>
Cover Shape:	<b>Circular</b>	Evidence of Surcharge:	<b>No</b>
Cover Size:	<b>22.5</b>	Potential for Runoff:	<b>None</b>
Comments:			

O&M Index:	<b>0.00</b>	O&M Quick:	<b>0000</b>	O&M Rating:	<b>0.00</b>
Structural Index:	<b>0.00</b>	Structural Quick:	<b>0000</b>	Structural Rating:	<b>0.00</b>
Overall Index:	<b>0.00</b>	Overall Quick:	<b>0000</b>	Overall Rating:	<b>0.00</b>


The diagram shows a vertical pole with a camera at the top. A red arrow labeled "Camera Direction" points downwards. A line connects the camera to a table of data. The table has five columns: Position, Code, Observation, Video (sec), and Grade. The data is as follows:

Position	Code	Observation	Video (sec)	Grade
.0	MGP	General Photo	10	NA
2.2	MGP	General Photo	28	NA
4.0	IS	Infil Stain	45	NA
4.0	IS	Infil Stain	57	NA
4.9	MGO	General Observation	71	NA



Code:	<b>MGP</b>
Description:	<b>General Photo</b>

Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code:	<b>MGP</b>
Description:	<b>General Photo</b>
Distance (ft):	<b>2.2</b>
Structural Grade:	<b>0</b>
O&M Grade:	<b>0</b>
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	<b>NO</b>
Remarks:	

---



Code:	<b>IS</b>
Description:	<b>Infil Stain</b>
Distance (ft):	<b>4.0</b>
Structural Grade:	<b>0</b>
O&M Grade:	<b>0</b>
Clock Start/From:	<b>4</b>
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	<b>NO</b>
Remarks:	

---



Code:	<b>IS</b>
Description:	<b>Infil Stain</b>
Distance (ft):	<b>4.0</b>
Structural Grade:	<b>0</b>
O&M Grade:	<b>0</b>
Clock Start/From:	<b>11</b>
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	<b>NO</b>
Remarks:	



Code:	<b>MGO</b>
Description:	<b>General Observation</b>
Distance (ft):	<b>4.9</b>
Structural Grade:	<b>0</b>
O&M Grade:	<b>0</b>
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	<b>NO</b>
Remarks:	<b>Ins. Comp.</b>