Manhole Inspection Report



05/07/2018 Date:

M-805-036.1

Weather:

Coding:

RZMACP

MH#:

Owner: NA Len. Surveyed: 3.4

P.O.#:

Surveyor: Jen Costello U-907-5518 Cert. #:

Rim to Invert: Wall Material:

Concrete

Street:

Customer:

South of Devonshire St. 107' East of Project:

(reinforced)

3.00

0.00

3.00

City:

Hobart, IN

GPS Northing:

Hobart, IN 2909198.682

Location:

South

GPS Easting:

2909198.682

Drain Area: Cover Shape:

GPS Accuracy:

Sub-Meter

Circular Cover Size: 22.5

Evidence of Surcharge: No Potential for Runoff: None

2111

Comments:

1.50 0.00

O&M Quick:

Structural Quick:


2111 O&M Rating: 0000

Structural Rating:

O&M Index: Structural Index: Overall Index:

1.50 Overall Quick: Overall Rating:

	Code	Observation	Video (sec)	Grade
05-036.1				
0.	RFJ	Roots Fine Joint	10	M 1
.0	MGO	General Observation	21	NA
0.	DAR	Deposits Attached Ragging	33	M 2
1.4	MGO	General Observation	49	NA
3.4	MGO	General Observation	66	NA



Description:	Roots Fine Joint		
Distance (ft):	.0		
Structural Grade:	0		
O&M Grade:	1		
Clock Start/From:	5		
Clock To:			
1st Value:			
2nd Value:			
Value Percent:			
Step:	NO		
Remarks:			

RFJ

Wednesday, May 3, 2023

Code:



Code: MGO

Description: General Observation

Distance (ft): .0
Structural Grade: 0
O&M Grade: 0
Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: ACCESS MH



Code: DAR

Description: Deposits Attached Ragging

Distance (ft): .0
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 3
Clock To:
1st Value:

Value Percent: 5.000 Step: NO


Remarks:

Code:

2nd Value:

Description: General Observation

MGO



Distance (ft): 1.4
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent:

Step:

Remarks: UNDERSIDE OF FRAME

NO

Wednesday, May 3, 2023



Code: MGO

Description: General Observation

Distance (ft): 3.4
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: END SURVEY