Manhole Inspection Report



Date: 05/07/2018 Weather: Coding: RZMACP

 MH#:
 M-805-059
 Owner:
 NA
 Len. Surveyed:
 4.5

 P.O.#:
 Surveyor:
 Jen Costello
 Rim to Invert:
 5.2

 Customer:
 Cert. #:
 U-907-5518
 Wall Material:
 Brick

Street: Devonshire St. 211' West of Ohio St. Project: Hobart, IN

City: Hobart, IN GPS Northing: 2908174.459

Location: GPS Easting: 2908174.459
Drain Area: South GPS Accuracy: Sub-Meter

Cover Shape: Circular Evidence of Surcharge: No
Cover Size: Potential for Runoff: None

Comments:

O&M Index:	2.00	O&M Quick:	2100	O&M Rating:	2.00
Structural Index:	3.00	Structural Quick:	3100	Structural Rating:	3.00
Overall Index:	2.50	Overall Quick:	3121	Overall Rating:	5.00

Wednesday, May 3, 2023

	Position	Code	Observation	Video (sec)	Grade				
M-805-05	M-805-059								
	0. //	MGP	General Photo	10	NA				
- 11	\.0	DB	Displaced Brick	21	S 3				
- 11	1.4	MGO	General Observation	37	NA				
- 11	3.3	OBB	Obstacle Brick	54	M 2				
- 11	4.5	MGO	General Observation	68	NA				
Camera Direction									

Code:



Description: **General Photo** Distance (ft): .0 Structural Grade: 0 O&M Grade: 0 Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Step: NO Remarks: **ACCESS MH**

MGP

Wednesday, May 3, 2023 2



Code: **DB**

Description: Displaced Brick

Distance (ft): .0
Structural Grade: 3
O&M Grade: 0
Clock Start/From: 12
Clock To: 12
1st Value:

2nd Value: Value Percent:

Step: NO

Remarks:



Code: MGO

Description: General Observation

Distance (ft): 1.4
Structural Grade: 0
O&M Grade: 0
Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: UNDERSIDE OF FRAME



Code: OBB

Description: Obstacle Brick

Distance (ft): 3.3
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 6
Clock To: 12
1st Value:

2nd Value:

Value Percent: 5.000 Step: NO

Remarks:

Wednesday, May 3, 2023



Code: MGO

Description: General Observation

Distance (ft): 4.5
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent:

Step: NO

Remarks: END SURVEY

Wednesday, May 3, 2023 4