
Date:	04/11/2018	Weather:		Coding:	RZMACP
MH#:	M-809-038	Owner:	NA	Len. Surveyed:	13.1
P.O.#:		Surveyor:	John Kuglmaier	Rim to Invert:	13.5
Customer:		Cert. #:	U-1215-07002349	Wall Material:	Concrete (reinforced)
Street:	Merganser St. 252' East of Kestrel St. Project: Hobart, IN				
City:	Hobart, IN	(GPS Northing:	2907565.653	
Location:		(GPS Easting:	2907565.653	
Drain Area:	Southwest	(GPS Accuracy:	Sub-Meter	
Cover Shape:	Circular	I	Evidence of Surcharge:	No	
Cover Size: Comments:	22.5	I	Potential for Runoff:	None	
O&M Index:	1.50	O&M Quick:	2111	O&M Rating:	3.00
Structural Index:	0.00	Structural Quid	ck: 0000	Structural Rating:	0.00
Overall Index:	1.50	Overall Quick:	2111	Overall Rating:	3.00

	Position	Code	Observation	Video (sec)	Grade
1-809-03	88				
\leq	.0	MGP	General Photo	10	NA
	\ <u>.</u> 0	RFJ	Roots Fine Joint	22	M 1
	1.8	IS	Infil Stain	37	NA
	2.4	MGP	General Photo	52	NA
	7.4	IS	Infil Stain	76	NA
	8.0	IS	Infil Stain	89	NA
	9.1	DAE	Deposits Attached Encrustation	103	M 2
	10.9	MGO	General Observation	118	NA



Code: Description:	MGP General Photo
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code:	RFJ
Description:	Roots Fine Joint
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	1
Clock Start/From:	1
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description:	IS Infil Stain
Distance (ft):	1.8
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	10
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description:	MGP General Photo
Distance (ft):	2.4
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code:	IS
Description:	Infil Stain
Distance (ft):	7.4
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	12
Clock To:	12
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description:	IS Infil Stain	
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Step: Remarks:	8.0 0 10 NO	



Code: Description:	DAE Deposits Attached Encrustation
Distance (ft):	9.1
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	4
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	5.000
Step:	NO
Remarks:	



Code:MGODescription:General Observation

Distance (ft):	10.9
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	Ins. Comp.