
RedZone **Manhole Inspection Report** ROBOTICS Date: 05/10/2018 Coding: RZMACP Weather: M-905-032 MH#: Owner: NA Len. Surveyed: 3.6 P.O.#: Jen Costello Rim to Invert: 3.8 Surveyor: U-907-5518 Vitrified Clay Customer: Cert. #: Wall Material: 193' East of Shelby St. 666' North of Project: Hobart, IN Street: City: Hobart, IN **GPS Northing:** 2911278.828 Location: **GPS Easting:** 2911278.828 Drain Area: Southeast **GPS Accuracy:** Sub-Meter Cover Shape: Circular Evidence of Surcharge: No Cover Size: 22.5 Potential for Runoff: None Comments: 0000 0.00 0.00 O&M Index: O&M Quick: **O&M** Rating: 7.00 3.50 5121 Structural Quick: Structural Index: Structural Rating: 5121 7.00 **Overall Index:** 3.50 **Overall Quick: Overall Rating:**

	Position	Code	Observation	Video (sec)	Grade
M-905-032					
	.0	MGP	General Photo	10	NA
	.0	SSS	Surface Spalling	22	S 2
	1.4	MGO	General Observation	38	NA
	1.4	В	Broken	48	S 5
	3.6	MGO	General Observation	66	NA
Camera Direction					



Code:	MGP	
Description:	General Photo	
	_	
Distance (ft):	.0	
Structural Grade:	0	
O&M Grade:	0	
Clock Start/From:		
Clock To:		
1st Value:		
2nd Value:		
Value Percent:		
Step:	NO	
Remarks:	ACCESS MH	



Code: Description:	SSS Surface Spalling
Distance (ft):	.0
Structural Grade:	2
O&M Grade:	0
Clock Start/From:	9
Clock To:	3
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description:	MGO General Observation
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Step:	1.4 0 0
Remarks:	UNDERSIDE OF FRAME



Code: Description:	B Broken
Distance (ft):	1.4
Structural Grade:	5
O&M Grade:	0
Clock Start/From:	8
Clock To:	11
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code:MGODescription:General Observation

Distance (ft):	3.6		
Structural Grade:	0		
O&M Grade:	0		
Clock Start/From:			
Clock To:			
1st Value:			
2nd Value:			
Value Percent:			
Step:	NO		
Remarks:	END SURVEY		