Date:	04/16/2018	Weather:		Coding:	RZMACP
MH#:	M-910-016	Owner:	NA	Len. Surveyed:	7.7
P.O.#:		Surveyor:	Jen Costello	Rim to Invert:	8.2
Customer:		Cert. #:	U-907-5518	Wall Material:	Concrete (reinforced)
Street:	Norris Dr. 1710' East of Randolph St. Project: He		Hobart, IN		
City:	Hobart, IN		GPS Northing:	2911718.303	
Location:			GPS Easting:	2911718.303	
Drain Area:	Southeast		GPS Accuracy:	Sub-Meter	
Cover Shape:	Circular		Evidence of Surcharge:	No	
Cover Size: Comments:	29.0		Potential for Runoff:	None	
O&M Index:	2.00	O&M Quick:	2100	O&M Rating:	2.00
Structural Index:	4.00	Structural Qui	ick: 4100	Structural Rating:	4.00
Overall Index:	3.00	Overall Quick	4121	Overall Rating:	6.00


	Position	Code	Observation	Video (sec)	Grade
910-01	16				
Ÿ	.0	MGO	General Observation	10	NA
	.0	RFB	Roots Fine Barrel	20	M 2
	1.3	MGO	General Observation	35	NA
	1.3	FM	Fracture Multiple	46	S 4
	7.7	MGO	General Observation	71	NA
Ш					



Code: Description:	MGO General Observation
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	ACCESS MH



Code:	RFB
Description:	Roots Fine Barrel
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	5
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code: Description:	MGO General Observation
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Step: Remarks:	1.3 0 0 NO UNDERSIDE OF FRAME
Remarks:	UNDERSIDE OF FRAME



Code: Description:	FM Fracture Multiple
Distance (ft):	1.3
Structural Grade:	4
O&M Grade:	0
Clock Start/From:	12
Clock To:	3
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	



Code:MGODescription:General Observation

Distance (ft):	7.7
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Step:	NO
Remarks:	END SURVEY