Date:	04/14/2018	Weather:		Coding:	PACP 6.0
Pipe Length (ft)	326.4	Owner:	NA	Pre Clean:	Not Known
P.O.#:		Surveyor:	Jen Costello	PSR:	P-1004-023-024
Customer:		Clean Date:	01/01/1900	Shape:	С
Street:	Drexel Dr.		Flow Control:	Not Controlled	
City:	Hobart, IN		Year Renewed:		
Location:	Other		Tape/Media #:		
Purpose:	Not Known		Dia/Height:	10"	
Use:	Sanitary		Material:	PVC	
Drain Area:	NA		Lining:		
Category:	NA				
Comment:					
Location Details	:		Direction of Survey	/: Downstream	
US MH:	M-1004-024	DS MH:	M-1004-023	Total Length Surveyed (ft)	: <b>319.1</b>
D&M Index:	2.00	O&M Quick:	2200	O&M Rating:	4.00
Structural Index:	0.00	Structural Qu	uick· 0000	Structural Rating:	0.00
Overall Index:	2.00	Overall Quick		Overall Rating:	4.00

	Position	Code	Observation	Video (sec)	Grade
м-100	4 024				
	.0	AMH	Manhole	10	NA
	.0	MWL	Water Level	21	NA
	59.3	TF	Tap Factory	151	NA
	/ 101.6	TF	Tap Factory	248	NA
- H	/ /140.4	DAGS	Deposits Attached Grease	338	M 2
	140.8	TF	Tap Factory	350	NA
	142.0	DAGS	Deposits Attached Grease	364	M 2
- H	_/ //241.3	TF	Tap Factory	575	NA
	310.7	TF	Tap Factory	727	NA
5	319.1	AMH	Manhole	757	NA
Camera Direction					
м-200	4-023				




Code: Description:	AMH Manhole
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-1004-024



Code: MWL Description: Water Level

Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Code: Description:	TF Tap Factory
Distance (ft):	59.3
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	11
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	
Remarks:	



Code:	TF
Description:	Tap Factory

Distance (ft):	101.6
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	1
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	



Code:	DAGS
Description:	Deposits Attached Grease

Distance (ft):	140.4
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	8
Clock To:	4
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	




Code:	TF
Description:	Tap Factory

Distance (ft):	140.8
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	11
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	
Remarks:	
Remarks:	



Code:	DAGS
Description:	Deposits Attached Grease

Distance (ft):	142.0
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	8
Clock To:	4
1st Value:	
2nd Value:	
Value Percent:	10.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Code:	TF
Description:	Tap Factory
Distance (ft):	241.3
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	10
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	
Remarks:	



Code: Description:	TF Tap Factory
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent:	310.7 0 0 2 4.000
Continuous Index: Within 8" of Joint: Remarks:	



Code: AMH Description: Manhole

Distance (ft):	319.1
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-1004-023