

Date:	03/24/2018	Weather:		Coding:	PACP 6.0
Pipe Length (ft)): 326.5	Owner:	NA	Pre Clean:	Not Known
P.O.#:		Surveyor:	Byrd Fitzgerald	PSR:	P-203-034-041
Customer:		Clean Date:	01/01/1900	Shape:	С
Street:	E 38th Ave		Flow Control:	Not Controlled	
City:	Hobart, IN		Year Renewed:		
Location:	Other		Tape/Media #:		
Purpose:	Not Known		Dia/Height:	12"	
Use:	Sanitary		Material:	VCP	
Drain Area:	NA		Lining:		
Category:	NA				
Comment:	pump				
Location Detail	s:		Direction of Surve	ey: Upstream	
US MH:	M-203-041	DS MH:	M-203-034	Total Length Surveyed (ft)	: 72.5
D&M Index:	2.00	O&M Quick:	2A00	O&M Rating:	28.00
Structural Index:	0.00	Structural Qu	uick: 0000		0.00
Overall Index:	2.00	Overall Quick			28.00

	Position	Code	Observation	Video (sec)	Grad
1(203-)03	34				
\sim	.0	AMH	Manhole	10	NA
	0.	MWL	Water Level	21	NA
Ň	.0	DSZ(S01)	Deposits Settled Other	33	M 2
	\ <u>.</u> 0	MGO	General Observation	44	NA
++	13.3	MWL	Water Level	82	NA
	63.7	MWL	Water Level	194	NA
	72.5	MSA	Abandoned Survey	224	NA
	72.5	DSZ(F01)	Deposits Settled Other	235	M 2
,					



Code: Description:	AMH Manhole
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-203-034

_



Code: Description:

MWL


Water Level

Distance (ft): .0 Structural Grade: 0 O&M Grade: 0 Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: 5.000 Continuous Index: Within 8" of Joint: NO Remarks:



Code:	DSZ
Description:	Deposits Settled Other

Distance (ft):	.0
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	6
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	S01
Within 8" of Joint:	NO
Remarks:	tissue



Code: MGO Description: **General Observation** Distance (ft): .0 Structural Grade: 0 O&M Grade: 0 Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

NO

MWL

heavy sediments in flow

Description:	Water Level
Distance (ft):	13.3
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	30.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	


Remarks:

Code:




Code: MWL Description: Water Level

Distance (ft):	63.7
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	50.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Code:	MSA
Description:	Abandoned Survey
Distance (ft):	72.5

Distance (It).	72.5
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	debris under water



Code:DSZDescription:Deposits Settled Other

Distance (ft):	72.5
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	6
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	F01
Within 8" of Joint:	NO
Remarks:	tissue