Profile/Photo Observation Report



Date: 03/25/2018 Weather: Coding: PACP 6.0

Pipe Length (ft): 78.7 Owner: NA Pre Clean: No Pre-Cleaning P.O.#: Surveyor: Byrd Fitzgerald PSR: P-209-026-027

Customer: Clean Date: 01/01/1900 Shape: C

Street: OFF E 61ST PL Flow Control: Not Controlled

City: Hobart, IN Year Renewed:
Location: Light Highway Tape/Media #:

Purpose: Routine Assessment Dia/Height: 10"
Use: Sanitary Material: VCP

Drain Area: NA Lining:

Category: NA
Comment: Flow direction wrong

Location Details: Direction of Survey: Upstream

US MH: M-209-027 DS MH: M-209-026 Total Length Surveyed (ft): 76.0

3222 2.20 11.00 O&M Index: O&M Quick: O&M Rating: 0.00 0000 0.00 Structural Quick: Structural Rating: Structural Index: 2.20 3222 11.00 Overall Quick: Overall Rating: Overall Index:

	Position	Code	Observation	Video (sec)	Grade
209-0	026				
\checkmark	0.	AMH	Manhole	10	NA
_	.0	MWL	Water Level	21	NA
	\\.0	DSZ	Deposits Settled Other	32	M 2
	\\3.8	TF	Tap Factory	53	NA
	15.2	RFJ	Roots Fine Joint	91	M 1
	44.6	MWL	Water Level	163	NA
	50.1	RMJ	Roots Medium Joint	186	M 3
	50.6	TFD	Tap Factory Defective	200	M 2
	50.6	RML	Roots Medium Lateral	211	M 3
	76.0	AMH	Manhole	274	NA

Code:



Description:	Manhole
Distance (ft): Structural Grade:	.0 0
O&M Grade:	0
Clock Start/From: Clock To:	
1st Value: 2nd Value:	
Value Percent: Continuous Index:	
Within 8" of Joint: Remarks:	NO M-209-026

AMH



Code: MWL

Description: Water Level

Distance (ft): .0
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 5.0

Continuous Index:

Within 8" of Joint:

Remarks:

5.000

NO

Code: DSZ

Description: Deposits Settled Other

6



Distance (ft): .0

Structural Grade: 0

O&M Grade: 2

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 5.000

Continuous Index:

Within 8" of Joint: **NO**Remarks: **debris**



Code: TF

Description: **Tap Factory**

Distance (ft): 3.8 Structural Grade: 0 0 O&M Grade: Clock Start/From: 11

Clock To:

1st Value: 4.000

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:



RFJ Code:

Description: **Roots Fine Joint**

Distance (ft): 15.2 Structural Grade: 0 O&M Grade: 1 Clock Start/From: 7 5 Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:



Code: MWL

Description: Water Level

Distance (ft): 44.6
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 25.000

Continuous Index:

Within 8" of Joint:

Remarks:

NO



Code: RMJ

Description: Roots Medium Joint

Distance (ft): 50.1
Structural Grade: 0

O&M Grade: 3

Clock Start/From: 2

Clock To: 5

1st Value:

1st Value: 2nd Value:

Value Percent: 5.000

Continuous Index:

Within 8" of Joint:

Remarks:

YES



Code: **TFD**

Description: Tap Factory Defective

Distance (ft): 50.6
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 11

Clock To:

1st Value: **4.000**

2nd Value: Value Percent: Continuous Index:

Within 8" of Joint:

Remarks: roots



Description: Roots Medium Lateral

YES



Distance (ft): 50.6
Structural Grade: 0

O&M Grade: 3

Clock Start/From: 7

Clock To: 5

1st Value: 2nd Value:

Value Percent: 10.000

Continuous Index:

Within 8" of Joint: NO

Remarks:



Code: AMH
Description: Manhole

Distance (ft): 76.0
Structural Grade: 0
O&M Grade: 0

Clock Start/From: Clock To: 1st Value:

2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: NO

Remarks: M-209-027