Date:	03/28/2018	Weather:		Coding:	PACP 6.0
Pipe Length (ft):	124.2	Owner:	NA	Pre Clean:	Not Known
P.O.#:		Surveyor:	Selasie Honu	PSR:	P-303-037-036
Customer:		Clean Date:	01/01/1900	Shape:	С
Street:	W 38TH AVE	Flow Control:		Not Controlled	
City:	Hobart, IN		Year Renewed:		
Location:	Other		Tape/Media #:		
Purpose:	Not Known		Dia/Height:	8"	
Use:	Sanitary		Material:	VCP	
Drain Area:	NA		Lining:		
Category:	NA				
Comment:					
Location Details	:		Direction of Surve	y: Upstream	
US MH:	M-303-036	DS MH:	M-303-037	Total Length Surveyed (ft)	: 123.6
D&M Index:	2.00	O&M Quick:	2B00	O&M Rating:	34.00
Structural Index:	0.00	Structural Qu	uick: 0000	Structural Rating:	0.00
Overall Index:	2.00	Overall Quic		Overall Rating:	34.00

		Position	Code	Observation	Video (sec)	Grade
M	303-0	37				
(	$\leq$	.0	AMH	Manhole	10	NA
		.0	MWL	Water Level	21	NA
		26.7	DAGS(S01)	Deposits Attached Grease	86	M 2
		/42.4	IW	Infil Weeper	129	M 2
		/ 44.0	TFA	Tap Factory Active	145	NA
		56.9	DAGS(F01)	Deposits Attached Grease	184	M 2
		73.9	DAGS(S02)	Deposits Attached Grease	229	M 2
		81.9	MMC	Material Change	256	NA
	===*	84.4	TF	Tap Factory	274	NA
U		84.8	MMC	Material Change	287	NA
Camera Direction		87.3	TBA	Tap Break-in Active	304	NA
		90.5	TFA	Tap Factory Active	323	NA
		122.4	DAGS(F02)	Deposits Attached Grease	400	M 2
Cai		123.6	AMH	Manhole	413	NA
- I						
- +						



Code: Description:	AMH Manhole
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-303-037

M(303-)036



Code: MWL Description: Water Level

Distance (ft): .0 Structural Grade: 0 O&M Grade: 0 Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: 5.000 Continuous Index: Within 8" of Joint: NO Remarks:

Code:	DAGS
Description:	<b>Deposits Attached Grease</b>

Distance (ft):	26.7
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	11
Clock To:	1
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	S01
Within 8" of Joint:	NO
Remarks:	



Code:	IW
Description:	Infil Weeper
Distance (ft):	42.4

0
2
8
4
YES




Code:	TFA
Description:	Tap Factory Active
Distance (ft):	44.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	9
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	
Remarks:	



Code:DAGSDescription:Deposits Attached Grease

Distance (ft):	56.9
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	11
Clock To:	1
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	F01
Within 8" of Joint:	NO
Remarks:	

Code: Description:




Distance (ft):	73.9
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	8
Clock To:	4
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	S02
Within 8" of Joint:	NO
Remarks:	

DAGS

**Deposits Attached Grease** 



MMC Material Change
81.9
0
0
NO
PVC



Code: Description:	TF Tap Factory
Distance (ft):	84.4
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	9
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	
Remarks:	



Code: Description:	MMC Material Change
Distance (ft):	84.8
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	vcp




Distance (ft):	87.3
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	12
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	
Remarks:	

ТВА

Tap Break-in Active

Code:

Description:



Code:TFADescription:Tap Factory Active

Distance (ft):	90.5
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	9
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	
Remarks:	

Code:	DAGS
Description:	Deposits Attached Grease

Distance (ft):	122.4
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	8
Clock To:	4
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	F02
Within 8" of Joint:	NO
Remarks:	



Code: AMH Description: Manhole

Distance (ft):	123.6
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-303-036