## **Profile/Photo Observation Report**



Date: 04/12/2018 Weather: **PACP 6.0** Coding: Pipe Length (ft): 183.8 Owner: NA Pre Clean: **Not Known** P.O.#: Surveyor: Jen Costello PSR: P-503-009-008

Customer: Clean Date: 01/01/1900 Shape: C

Street: W 40TH AVE Flow Control: Not Controlled

City: Hobart, IN Year Renewed: Location: Other Tape/Media #:

Purpose: Not Known Dia/Height: 12"
Use: Sanitary Material: VCP

Drain Area: NA Lining:

Category: NA

Comment:

Location Details: Direction of Survey: **Downstream** 

US MH: M-503-008 DS MH: M-503-009 Total Length Surveyed (ft): 203.9

1.75 2311 7.00 O&M Index: O&M Quick: O&M Rating: 3.00 12.00 Structural Quick: Structural Rating: Structural Index: 2.38 19.00 Overall Index: Overall Quick: Overall Rating:

.0 .0 4.8 9.9 12.3 26.3 47.3		Manhole Water Level Fracture Longitudinal Tap Factory Surface Spalling	10 22 43 67	NA NA S 3 NA
.0 .0 4.8 9.9 12.: 26.:	MWL FL TF SSS	Water Level Fracture Longitudinal Tap Factory	22 43 67	NA S 3
4.8 9.9 12 26	FL TF 3 SSS	Fracture Longitudinal Tap Factory	43 67	S 3
9.9	TF 3 SSS	Tap Factory	67	
\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\	3 SSS			NA
\\26.3		Surface Spalling		
\ <u>\</u>	2 TF		85	S 2
47.:		Tap Factory	127	NA
	1 MMC	Material Change	182	NA
57.0	6 MMC	Material Change	214	NA
71.	1 TF	Tap Factory	255	NA
94.0	) FS	Fracture Spiral	315	S 3
95.	3 TF	Tap Factory	331	NA
97.	5 TF	Tap Factory	351	NA
124	.9 RFJ	Roots Fine Joint	420	M 1
/139	.1 IW	Infil Weeper	461	M 2
/ / 152	.8 FM	Fracture Multiple	501	S 4
//152	.8 IW	Infil Weeper	512	M 2
// 155	.2 DAE	Deposits Attached Encrustation	529	M 2
203	.9 AMH	Manhole	638	NA

Code:

Description:



Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-503-008

AMH

Manhole



Code: MWL

Description: **Water Level** 

Distance (ft): .0 Structural Grade: 0 O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent:

Continuous Index:

Within 8" of Joint:

Remarks:

5.000

NO



Code: FL

Description: **Fracture Longitudinal** 

Distance (ft): 4.8 Structural Grade: 3 O&M Grade: 0 Clock Start/From: 12 Clock To: 1st Value:

2nd Value: Value Percent: Continuous Index:

Within 8" of Joint:

Remarks:

YES



Code: **TF** 

Description: Tap Factory

Distance (ft): 9.9
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 10

Clock To:

1st Value: **4.000** 

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:




Code: SSS

Description: Surface Spalling

Distance (ft): 12.3
Structural Grade: 2
O&M Grade: 0
Clock Start/From: 11
Clock To: 1
1st Value:
2nd Value:
Value Percent:
Continuous Index:

Within 8" of Joint: YES



Code: **TF** 

Description: Tap Factory

Distance (ft): 26.2
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 11

Clock To:

1st Value:

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:

Code: MMC

Description: Material Change

4.000



Distance (ft): 47.1
Structural Grade: 0

O&M Grade: **0** 

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: NO Remarks: PVC



Code: MMC

Description: Material Change

Distance (ft): 57.6
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: NO Remarks: vcp

Code: **TF** 

Description: Tap Factory



Distance (ft): 71.1
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 11

Clock To:

1st Value: **4.000** 

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:



Code: FS

Description: Fracture Spiral

Distance (ft): 94.0
Structural Grade: 3
O&M Grade: 0
Clock Start/From: 10
Clock To: 11

1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint:

Remarks:

YES



Code: **TF** 

Description: Tap Factory

Distance (ft): 95.3
Structural Grade: 0

O&M Grade: 0

Clock Start/From: 11

Clock To:

1st Value: **4.000** 

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:



Code: **TF** 

Description: Tap Factory

Distance (ft): 97.5
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 1

Clock To:

1st Value: **4.000** 

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:

Code: RFJ

Description: Roots Fine Joint



Distance (ft): 124.9
Structural Grade: 0

O&M Grade: 1
Clock Start/From: 11
Clock To: 1

1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: YES



Code: IW

Description: Infil Weeper

Distance (ft): 139.1
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 1
Clock To: 4

1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint:

Remarks:

YES




Code: FM
Description: Fracture Multiple

Distance (ft): 152.8
Structural Grade: 4
O&M Grade: 0
Clock Start/From: 11
Clock To: 1

1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: YES



Code: IW

Description: Infil Weeper

Distance (ft): 152.8 Structural Grade: 0 2 O&M Grade: Clock Start/From: 1 Clock To: 4

1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint:

Remarks:

5.000

YES

Code: DAE Description: **Deposits Attached Encrustation** 



Distance (ft): 155.2 Structural Grade: 0 O&M Grade: 2 Clock Start/From: 1

4 Clock To: 1st Value: 2nd Value:

Value Percent:

Continuous Index:

Within 8" of Joint: YES



Code: AMH
Description: Manhole

Distance (ft): 203.9
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: NO

Remarks: M-503-009