

Profile/Photo Observation Report



Date:	04/09/2018	Weather:		Coding:	PACP 6.0
Pipe Length (ft):	331.2	Owner:	NA	Pre Clean:	Not Known
P.O.#:		Surveyor:	Byrd Fitzgerald	PSR:	P-503-033-032
Customer:		Clean Date:	01/01/1900	Shape:	C

Street:	W 41ST AVE	Flow Control:	Not Controlled
City:	Hobart, IN	Year Renewed:	
Location:	Other	Tape/Media #:	
Purpose:	Not Known	Dia/Height:	10"
Use:	Sanitary	Material:	CP
Drain Area:	NA	Lining:	
Category:	NA		
Comment:			

Location Details:		Direction of Survey:	Downstream
US MH:	M-503-032	DS MH:	M-503-033
		Total Length Surveyed (ft):	29.1

O&M Index:	4.00	O&M Quick:	4100	O&M Rating:	4.00
Structural Index:	2.67	Structural Quick:	3511	Structural Rating:	16.00
Overall Index:	2.86	Overall Quick:	4135	Overall Rating:	20.00

The diagram shows a vertical pipe with inspection points marked by circles at the top and bottom, labeled M-503-032 and M-503-033 respectively. A red arrow on the left indicates the camera direction, pointing downwards. A table on the right lists inspection data for the pipe.

Position	Code	Observation	Video (sec)	Grade
.0	AMH	Manhole	10	NA
.0	MWL	Water Level	21	NA
.0	CC	Crack Circumferential	33	S 1
2.5	SAV(S01)	Surface Aggregate Visible	50	S 3
28.5	RBJ	Roots Ball Joint	113	M 4
29.1	MSA	Abandoned Survey	126	NA
29.1	SAV(F01)	Surface Aggregate Visible	137	S 3

Code: **AMH**
Description: **Manhole**




Code:	MWL
Description:	Water Level




Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	

Code:	CC
Description:	Crack Circumferential




Distance (ft):	.0
Structural Grade:	1
O&M Grade:	0
Clock Start/From:	1
Clock To:	5
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	
Remarks:	

Code: **SAV**
Description: **Surface Aggregate Visible**



Distance (ft): **2.5**
Structural Grade: **3**
O&M Grade: **0**
Clock Start/From: **7**
Clock To: **5**
1st Value:
2nd Value:
Value Percent:
Continuous Index: **S01**
Within 8" of Joint:
Remarks:

Code: **RBJ**
Description: **Roots Ball Joint**



Distance (ft): **28.5**
Structural Grade: **0**
O&M Grade: **4**
Clock Start/From: **2**
Clock To: **10**
1st Value:
2nd Value:
Value Percent: **75.000**
Continuous Index:
Within 8" of Joint: **YES**
Remarks:

Code: **MSA**
Description: **Abandoned Survey**



Distance (ft): **29.1**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From:
Clock To:
1st Value:
2nd Value:
Value Percent:
Continuous Index:
Within 8" of Joint: **NO**
Remarks: **rbj**

Code: **SAV**
Description: **Surface Aggregate Visible**



Distance (ft): **29.1**
Structural Grade: **3**
O&M Grade: **0**
Clock Start/From: **7**
Clock To: **5**
1st Value:
2nd Value:
Value Percent:
Continuous Index: **F01**
Within 8" of Joint:
Remarks: