Profile/Photo Observation Report

Location:



Date: 04/25/2018 Weather: Coding: **PACP 6.0** Pipe Length (ft): NA Pre Clean: 157.2 Owner: **Not Known** P.O.#: Surveyor: Jen Costello PSR: P-504-006-005

Customer: Clean Date: 01/01/1900 Shape: C

Street: N CALIFORNIA ST & W HOME AVE Flow Control: Not Controlled

City: Hobart, IN Year Renewed:

Purpose: Not Known Dia/Height: 12"
Use: Sanitary Material: VCP

Drain Area: NA Lining:

Category: NA

Light Highway

Comment:

Location Details: Direction of Survey: Upstream

US MH: M-504-005 DS MH: M-504-006 Total Length Surveyed (ft): 106.3

O&M Index:	2.32	O&M Quick:	3B2G	O&M Rating:	137.00
Structural Index:	3.05	Structural Quick:	413C	Structural Rating:	64.00
Overall Index:	2.51	Overall Quick:	413F	Overall Rating:	201.00

Tape/Media #:

	Position	Code	Observation	Video (sec)	Grade
504-0	006				
	0.	AMH	Manhole	10	NA
	.0	MWL	Water Level	21	NA
	6.1	DAE	Deposits Attached Encrustation	47	M 2
	10.2	FL	Fracture Longitudinal	68	S 3
	10.2	DAE	Deposits Attached Encrustation	80	M 2
	13.7	FL(S01)	Fracture Longitudinal	99	S 3
	13.7	DAE(S02)	Deposits Attached Encrustation	110	M 2
	15.5	IW	Infil Weeper	126	M 2
	18.0	ID	Infil Dripper	143	M 3
	23.6	IW(S03)	Infil Weeper	166	M 2
	23.6	RMJ(S04)	Roots Medium Joint	177	M 3
	76.4	IW	Infil Weeper	294	M 2
	90.1	FM	Fracture Multiple	333	S 4
	104.3	RMJ	Roots Medium Joint	373	M 3
	106.3	DAE(F02)	Deposits Attached Encrustation	388	M 2
	106.3	IW(F03)	Infil Weeper	399	M 2
	106.3	RMJ(F04)	Roots Medium Joint	411	M 3
	106.3	FL(F01)	Fracture Longitudinal	422	S 3
	106.3	MSA	Abandoned Survey	433	NA

Code:	AMH		
Description:	Manhole		
Distance (ft):	.0		
Structural Grade:	0		
O&M Grade:	0		
Clock Start/From:			
Clock To:			
1st Value:			
2nd Value:			
Value Percent:			
Continuous Index:			
Within 8" of Joint:	NO		
Remarks:	M-504-005		



Code: MWL

Description: **Water Level**

Distance (ft): .0 Structural Grade: 0 O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 10.000

Continuous Index:

Within 8" of Joint:

Remarks:

NO



Code: DAE

Description: **Deposits Attached Encrustation**

Distance (ft): 6.1 Structural Grade: 0 O&M Grade: 2 Clock Start/From: 1 Clock To: 4 1st Value:

Value Percent: 5.000

Continuous Index:

Within 8" of Joint: YES

Remarks:

2nd Value:



Code: FL

Description: Fracture Longitudinal

Distance (ft): 10.2
Structural Grade: 3
O&M Grade: 0
Clock Start/From: 12

Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:

Code: DAE

Description: Deposits Attached Encrustation

NO




Distance (ft): 10.2
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 10
Clock To: 12

1st Value: 2nd Value:

Value Percent: 5.000

Continuous Index:

Within 8" of Joint:



Code: FL

Description: Fracture Longitudinal

Distance (ft): 13.7
Structural Grade: 3
O&M Grade: 0
Clock Start/From: 12

Clock To: 1st Value: 2nd Value: Value Percent:

Continuous Index: **S01**Within 8" of Joint: **YES**

Remarks:

Code: DAE

Description: Deposits Attached Encrustation



Distance (ft): 13.7
Structural Grade: 0

O&M Grade: 2

Clock Start/From: 8

Clock To: 4

1st Value:

2nd Value:
Value Percent: 5.000
Continuous Index: \$02
Within 8" of Joint: YES



Description: Infil Weeper

Distance (ft): 15.5
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 3

Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:



Code: ID

Description: Infil Dripper

Distance (ft): 18.0
Structural Grade: 0
O&M Grade: 3
Clock Start/From: 12
Clock To:
1st Value:
2nd Value:

Value Percent: Continuous Index:

Within 8" of Joint: YES



Description: Infil Weeper

Distance (ft): 23.6
Structural Grade: 0

O&M Grade: 2

Clock Start/From: 8

Clock To: 4

1st Value:

1st Value: 2nd Value: Value Percent:

Continuous Index: **S03**Within 8" of Joint: **YES**

Remarks:

Code: RMJ

Description: Roots Medium Joint



Distance (ft): 23.6
Structural Grade: 0
O&M Grade: 3
Clock Start/From: 8
Clock To: 4
1st Value:

Value Percent: 10.000
Continuous Index: S04
Within 8" of Joint: YES

Remarks:

2nd Value:



Description: Infil Weeper

Distance (ft): 76.4
Structural Grade: 0

O&M Grade: 2

Clock Start/From: 8

Clock To: 4

1st Value: 2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:

Code: FM
Description: Fracture Multiple

Distance (ft): 90.1
Structural Grade: 4

O&M Grade: 0

Clock Start/From: 8


Clock To: 4

1st Value:
2nd Value:
Value Percent:
Continuous Index:

Within 8" of Joint:

YES





Code: RMJ

Description: Roots Medium Joint

Distance (ft): 104.3
Structural Grade: 0
O&M Grade: 3
Clock Start/From: 8
Clock To: 4

1st Value: 2nd Value:

Value Percent: 40.000

Continuous Index:

Within 8" of Joint:

Remarks:

YES



Code: DAE

Description: Deposits Attached Encrustation

Distance (ft): 106.3
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 8
Clock To: 4
1st Value:
2nd Value:

Value Percent: 5.000
Continuous Index: F02
Within 8" of Joint: YES



Description: Infil Weeper

Distance (ft): 106.3
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 8
Clock To: 4

1st Value: 2nd Value: Value Percent:

Continuous Index: F03
Within 8" of Joint: YES

Remarks:

Code: RMJ

Description: Roots Medium Joint



Distance (ft): 106.3
Structural Grade: 0
O&M Grade: 3
Clock Start/From: 8
Clock To: 4

Clock To: 1st Value: 2nd Value: Value Percen

Value Percent: 10.000
Continuous Index: F04
Within 8" of Joint: YES



Code: FL

Description: Fracture Longitudinal

Distance (ft): 106.3
Structural Grade: 3
O&M Grade: 0
Clock Start/From: 12

Clock To: 1st Value: 2nd Value: Value Percent:

Continuous Index: F01
Within 8" of Joint: YES

Remarks:

Code: MSA

Description: Abandoned Survey



Distance (ft): 106.3
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To:
1st Value:
2nd Value:
Value Percent:
Continuous Index:

Within 8" of Joint: NO Remarks: roots