Profile/Photo Observation Report



Date: 04/18/2018 Weather: **PACP 6.0** Coding: Pipe Length (ft): 237.6 Owner: NA Pre Clean: **Not Known** P.O.#: **Byrd Fitzgerald** PSR: P-504-049-048 Surveyor:

Customer: Clean Date: 01/01/1900 Shape: C

Street: N COLORADO ST Flow Control: Not Controlled

City: Hobart, IN Year Renewed:
Location: Light Highway Tape/Media #:

Purpose: Not Known Dia/Height: 10"
Use: Sanitary Material: VCP

Drain Area: NA Lining:

Category: NA

Comment:

Location Details: Direction of Survey: Downstream

US MH: M-504-048 DS MH: M-504-049 Total Length Surveyed (ft): 198.5

1.83 2511 11.00 O&M Index: O&M Quick: O&M Rating: 0.00 0000 0.00 Structural Quick: Structural Rating: Structural Index: 1.83 2511 11.00 Overall Rating: Overall Index: Overall Quick:

	Position	Code	Observation	Video (sec)	Grade
504-0	48				
	0	AMH	Manhole	10	NA
<u> </u>	0.	MWL	Water Level	21	NA
	13.1	TFC	Tap Factory Capped	59	NA
\ \	14.9	DSZ	Deposits Settled Other	74	M 2
	19.1	MWL	Water Level	94	NA
 	√38.2	TFC	Tap Factory Capped	143	NA
	52.3	TBI	Tap Break-in Intruding	184	M 2
<u> </u>	52.3	RFJ	Roots Fine Joint	196	M 1
/	64.0	TFC	Tap Factory Capped	232	NA
	89.1	TFC	Tap Factory Capped	294	NA
	90.8	TBI	Tap Break-in Intruding	309	M 2
	106.4	TF	Tap Factory	352	NA
	114.0	TFC	Tap Factory Capped	379	NA
	138.8	TF	Tap Factory	441	NA
	/139.8	IW	Infil Weeper	454	M 2
	/167.0	TFC	Tap Factory Capped	521	NA
	175.2	DAE	Deposits Attached Encrustation	549	M 2
	189.8	TFC	Tap Factory Capped	590	NA
	//198.5	AMH	Manhole	619	NA

Code:



Description:	Manhole		
Distance (ft):	.0		
Structural Grade:	0		
O&M Grade:	0		
Clock Start/From:			
Clock To:			
1st Value:			
2nd Value:			
Value Percent:			
Continuous Index:			
Within 8" of Joint:	NO		
Remarks:	M-504-048		

AMH



Code: MWL

Description: Water Level

Distance (ft): .0
Structural Grade: 0
O&M Grade: 0
Clock Start/From:

Clock Start/From: Clock To:

1st Value: 2nd Value:

Value Percent: 5.000

Continuous Index:

Within 8" of Joint:

Remarks:

NO

Code: **TFC**

Description: Tap Factory Capped



Distance (ft): 13.1
Structural Grade: 0

O&M Grade: 0

Clock Start/From: 1

Clock To:

1st Value: **4.000**

2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: YES



Code: DSZ

Description: Deposits Settled Other

Distance (ft): 14.9
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 6

Clock To: 1st Value: 2nd Value:

Value Percent: 10.000

Continuous Index:

Within 8" of Joint: NO Remarks: debris



Code: MWL

Description: Water Level

Distance (ft): 19.1
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 25.000

Continuous Index:

Within 8" of Joint: NO



Code: TFC

Description: **Tap Factory Capped**

Distance (ft): 38.2 Structural Grade: 0 0 O&M Grade: Clock Start/From: 1

Clock To:

1st Value: 4.000

2nd Value: Value Percent: Continuous Index:

Within 8" of Joint:

YES

Remarks:



TBI Code:

Description: **Tap Break-in Intruding**

Distance (ft): 52.3 Structural Grade: 0 O&M Grade: 2 Clock Start/From: 2

Clock To:

1st Value: 4.000 2nd Value: 1.000

Value Percent: Continuous Index:

Within 8" of Joint: YES



Code: RFJ

Description: Roots Fine Joint

Distance (ft): 52.3
Structural Grade: 0

O&M Grade: 1

Clock Start/From: 1

Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint:

Remarks:

YES



Code: **TFC**

Description: Tap Factory Capped


Distance (ft): 64.0
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 1

Clock To:

1st Value: **4.000**

2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: YES



Code: TFC

Description: Tap Factory Capped

Distance (ft): 89.1
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 1

Clock To:

1st Value: **4.000**

2nd Value: Value Percent: Continuous Index:

Within 8" of Joint:

Remarks:

YES



Code: TBI

Description: Tap Break-in Intruding

Distance (ft): 90.8
Structural Grade: 0


O&M Grade: 2

Clock Start/From: 1

Clock To:

1st Value: **4.000**2nd Value: **1.000**

Value Percent: Continuous Index: Within 8" of Joint:



Code: **TF**

Description: Tap Factory

Distance (ft): 106.4
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 11

Clock To:

1st Value: **4.000**


2nd Value: Value Percent: Continuous Index:

Within 8" of Joint:

Remarks:

YES

TFC



Tap Factory Capped



Distance (ft): 114.0
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 1

Clock To:

1st Value: **4.000**

2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: YES



Code: TF

Description: **Tap Factory**

Distance (ft): 138.8 Structural Grade: 0 O&M Grade: 0 Clock Start/From: 1

Clock To:

1st Value: 4.000

2nd Value: Value Percent: Continuous Index:

Within 8" of Joint:

YES

Remarks:



Code: IW

Description: Infil Weeper

Distance (ft): 139.8 Structural Grade: 0 O&M Grade: 2 Clock Start/From: 2 4 Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: YES



Code: TFC

Description: **Tap Factory Capped**

Distance (ft): 167.0 Structural Grade: 0 O&M Grade: 0 Clock Start/From: 1

Clock To:

1st Value: 4.000

2nd Value: Value Percent: Continuous Index:

Within 8" of Joint:

YES

Remarks:



Code: DAE

Description: **Deposits Attached Encrustation**

Distance (ft): 175.2 Structural Grade: 0 O&M Grade: 2 Clock Start/From: 8 Clock To: 4 1st Value:

Value Percent: Continuous Index:


5.000

Within 8" of Joint:

YES

Remarks:

2nd Value:



Code: TFC

Description: **Tap Factory Capped**

YES

0

Distance (ft): 189.8 Structural Grade: 0 0 O&M Grade: Clock Start/From: 1

Clock To:

1st Value: 4.000

2nd Value: Value Percent: Continuous Index:

Within 8" of Joint:

Remarks:

AMH Code: Description: Manhole



Distance (ft): 198.5 Structural Grade: 0

O&M Grade: Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: NO

Remarks: M-504-049