

Profile/Photo Observation Report



Date:	04/19/2018	Weather:		Coding:	PACP 6.0
Pipe Length (ft):	161.5	Owner:	NA	Pre Clean:	Not Known
P.O.#:		Surveyor:	Byrd Fitzgerald	PSR:	P-504-065.2-065.1
Customer:		Clean Date:	01/01/1900	Shape:	C

Street:	N GUYER ST	Flow Control:	Not Controlled
City:	Hobart, IN	Year Renewed:	
Location:	Light Highway	Tape/Media #:	
Purpose:	Not Known	Dia/Height:	8"
Use:	Sanitary	Material:	CP
Drain Area:	NA	Lining:	
Category:	NA		
Comment:			
Location Details:		Direction of Survey:	Downstream
US MH:	M-504-065.1	DS MH:	M-504-065.2
		Total Length Surveyed (ft):	124.1

O&M Index:	0.00	O&M Quick:	0000	O&M Rating:	0.00
Structural Index:	2.11	Structural Quick:	3D1C	Structural Rating:	95.00
Overall Index:	2.11	Overall Quick:	3D1C	Overall Rating:	95.00

Position	Code	Observation	Video (sec)	Grade
M-504-065.1				
.0	AMH	Manhole	10	NA
.0	MWL	Water Level	21	NA
.0	MGO	General Observation	32	NA
.0	SAV(S02)	Surface Aggregate Visible	44	S 3
17.6	CC	Crack Circumferential	91	S 1
20.4	TBA	Tap Break-in Active	110	NA
30.9	CC(S01)	Crack Circumferential	143	S 1
47.0	MWL	Water Level	187	NA
65.4	TF	Tap Factory	235	NA
117.8	MWL	Water Level	352	NA
122.6	TF	Tap Factory	373	NA
124.1	AEP	End of Pipe	388	NA
124.1	CC(F01)	Crack Circumferential	399	S 1
124.1	SAV(F02)	Surface Aggregate Visible	411	S 3
M-504-065.2				



Code: **AMH**
Description: **Manhole**

Distance (ft): **.0**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From:
Clock To:
1st Value:
2nd Value:
Value Percent:
Continuous Index:
Within 8" of Joint: **NO**
Remarks: **M-504-065.1**

Code:	MWL
Description:	Water Level




Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	25.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	

Code:	MGO
Description:	General Observation



Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	steam

Code: **SAV**
Description: **Surface Aggregate Visible**



Distance (ft): **.0**
Structural Grade: **3**
O&M Grade: **0**
Clock Start/From: **8**
Clock To: **4**
1st Value:
2nd Value:
Value Percent:
Continuous Index: **S02**
Within 8" of Joint:
Remarks:

Code: **CC**
Description: **Crack Circumferential**



Distance (ft): **17.6**
Structural Grade: **1**
O&M Grade: **0**
Clock Start/From: **8**
Clock To: **4**
1st Value:
2nd Value:
Value Percent:
Continuous Index:
Within 8" of Joint:
Remarks:

Code: **TBA**
Description: **Tap Break-in Active**




Distance (ft): **20.4**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From: **10**
Clock To:
1st Value: **4.000**
2nd Value:
Value Percent:
Continuous Index:
Within 8" of Joint: **YES**
Remarks:

Code: **CC**
Description: **Crack Circumferential**



Distance (ft): **30.9**
Structural Grade: **1**
O&M Grade: **0**
Clock Start/From: **8**
Clock To: **4**
1st Value:
2nd Value:
Value Percent:
Continuous Index: **S01**
Within 8" of Joint:
Remarks: **thru out pipe**

Code: **MWL**
Description: **Water Level**




Distance (ft): **47.0**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From:
Clock To:
1st Value:
2nd Value:
Value Percent: **5.000**
Continuous Index:
Within 8" of Joint: **NO**
Remarks:

Code: **TF**
Description: **Tap Factory**



Distance (ft): **65.4**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From: **3**
Clock To:
1st Value: **4.000**
2nd Value:
Value Percent:
Continuous Index:
Within 8" of Joint: **YES**
Remarks:

Code: **MWL**
Description: **Water Level**




Distance (ft): **117.8**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From:
Clock To:
1st Value:
2nd Value:
Value Percent: **50.000**
Continuous Index:
Within 8" of Joint: **NO**
Remarks:

Code: **TF**
Description: **Tap Factory**




Distance (ft): **122.6**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From: **3**
Clock To:
1st Value: **4.000**
2nd Value:
Value Percent:
Continuous Index:
Within 8" of Joint: **YES**
Remarks:

Code: **AEP**
Description: **End of Pipe**




Distance (ft): **124.1**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From:
Clock To:
1st Value:
2nd Value:
Value Percent:
Continuous Index:
Within 8" of Joint: **NO**
Remarks: **M-504-065.2**

Code: **CC**
Description: **Crack Circumferential**



Distance (ft): **124.1**
Structural Grade: **1**
O&M Grade: **0**
Clock Start/From: **8**
Clock To: **4**
1st Value:
2nd Value:
Value Percent:
Continuous Index: **F01**
Within 8" of Joint:
Remarks: **thru out pipe**



Code:	SAV
Description:	Surface Aggregate Visible
Distance (ft):	124.1
Structural Grade:	3
O&M Grade:	0
Clock Start/From:	8
Clock To:	4
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	F02
Within 8" of Joint:	
Remarks:	