
Date:	04/08/2018	Weather:			Coding:	PACP 6.0
Pipe Length (ft	:):	Owner:	City of Hobart		Pre Clean:	No Pre-Cleaning
P.O.#:	21-2	Surveyor:	M. Pielacha		PSR:	M-504-075-M-504-074
Customer:	City of Hobart	Clean Date:			Shape:	С
Street:	Off Colorado Street		Flow Control:		Not Controlled	
City:	Hobart, IN		Year Renewed:			
Location:	Light Highway		Tape/Media #:		DEP 21	
Purpose:	Routine Assessmen	t	Dia/Height:		18"	
Use:	Sanitary		Material:		VCP	
Drain Area:			Lining:			
Category:	NA					
Comment:						
Location Detai	ls:		Direction of Surv	vey:	Downstream	
US MH:	M-504-075	DS MH:	M-504-074	Total Len	gth Surveyed (ft)	222.7
D&M Index:	3.00	O&M Quick:	340	<mark>)0 </mark> C	0&M Rating:	12.00
Structural Index	0.00	Structural Qu	uick: 000	0	tructural Rating:	0.00
Overall Index:	3.00	Overall Quick			Verall Rating:	12.00

	Position	Code	Observation	Video (sec)	Grade
n(504-)	075				
<u> </u>	0.	AMH	Manhole	0	NA
	.0	MWL	Water Level	7	NA
	80.3	ТВА	Tap Break-in Active	104	NA
	122.1	ТВ	Tap Break-in	177	NA
	134.3	TBA	Tap Break-in Active	204	NA
	166.1	TBD	Tap Break-in Defective	255	M 3
	166.1	RML	Roots Medium Lateral	260	M 3
	208.7	OBZ	Obstacle Other	350	M 3
	221.0	RMJ	Roots Medium Joint	400	M 3
	222.7	AMH	Manhole	415	NA



Code: Description:	AMH Manhole
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-504-075

Friday, October 1, 2021



Code:	MWL
Description:	Water Level
Distance (ft):	0
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Code: Description:	TBA Tap Break-in Active
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent:	80.3 0 0 12 4.000
Continuous Index: Within 8" of Joint: Remarks:	NO



Code:	тв
Description:	Tap Break-in
Distance (ft):	122.1
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	10
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Code: Description:	TBA Tap Break-in Active
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index: Within 8" of Joint: Remarks:	134.3 0 0 2 4.000 NO



TBD Tap Break-in Defective
166.1
0
3
12
4.000
NO
Defective



Code: Description:	RML Roots Medium Lateral
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index: Within 8" of Joint: Remarks:	166.1 0 3 12 5.000 NO



Code:	OBZ
Description:	<b>Obstacle Other</b>
/0	
Distance (ft):	208.7
Structural Grade:	0
O&M Grade:	3
Clock Start/From:	5
Clock To:	7
1st Value:	
2nd Value:	
Value Percent:	15.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	Debris



Code:	RMJ
Description:	Roots Medium Joint
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index: Within 8" of Joint: Remarks:	221.0 0 3 6 12 25.000 YES



Code:	AMH
Description:	Manhole
Distance (ft):	222.7
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-504-074