

# Profile/Photo Observation Report



Date:	09/05/2021	Weather:		Coding:	PACP 7.0
Pipe Length (ft):	195.3	Owner:	City of Hobart	Pre Clean:	Heavy Cleaning
P.O.#:	YES502259	Surveyor:	S. Bucklin	PSR:	P-504-077-076
Customer:	City of Hobart	Clean Date:	09/02/2021	Shape:	C

Street:	North Cavender Street	Flow Control:	Not Controlled
City:	Hobart, IN	Year Renewed:	
Location:	Alley	Tape/Media #:	
Purpose:	Routine Assessment	Dia/Height:	12"
Use:	Sanitary Sewage Pipe	Material:	VCP
Drain Area:		Lining:	
Category:	NA		
Comment:			
Location Details:		Direction of Survey:	Downstream
US MH:	M-504-077	DS MH:	M-504-076
		Total Length Surveyed (ft):	195.3


O&M Index:	2.08	O&M Quick:	4336	O&M Rating:	154.00
Structural Index:	3.11	Structural Quick:	4A3A	Structural Rating:	84.00
Overall Index:	2.36	Overall Quick:	4A3B	Overall Rating:	238.00

Position	Code	Observation	Video (sec)	Grade
.0	AMH	Manhole	1	NA
.0	MWL	Miscellaneous Water Level	62	NA
.0	CM	Crack Multiple	111	S 3
5.3	RFJ	Roots Fine Joint	182	M 1
5.3	CM	Crack Multiple	208	S 3
7.3	DAE	Deposits Attached Encrustation	265	M 2
7.3	FM	Fracture Multiple	301	S 4
20.3	DAE	Deposits Attached Encrustation	444	M 2
20.3	DAE	Deposits Attached Encrustation	468	M 2
21.0	DSF(S01)	Deposits Settled Fine	525	M 2
21.0	OBM	Obstruction Pipe Material in Invert	564	M 2
22.4	DAE	Deposits Attached Encrustation	599	M 2
22.4	DAE	Deposits Attached Encrustation	625	M 2
39.5	CL	Crack Longitudinal	834	S 2
41.6	DAE	Deposits Attached Encrustation	883	M 2
41.6	CL	Crack Longitudinal	899	S 2
41.6	CL	Crack Longitudinal	916	S 2
41.6	DAE	Deposits Attached Encrustation	933	M 2
56.1	RMJ	Roots Medium Joint	1055	M 3

58.7	RFJ	Roots Fine Joint	1106	M 1
67.3	CL	Crack Longitudinal	1210	S 2
77.8	DAE	Deposits Attached Encrustation	1318	M 2
82.2	CM	Crack Multiple	1388	S 3
86.5	DAE	Deposits Attached Encrustation	1435	M 2
90.3	B	Broken	1528	S 4
90.6	DAE	Deposits Attached Encrustation	1573	M 2
91.7	TFD	Tap Factory Defective	1612	M 3
91.7	RFL	Roots Fine Lateral	1626	M 1
97.2	DAE	Deposits Attached Encrustation	1716	M 2
99.4	CM	Crack Multiple	1774	S 3
99.4	DAE	Deposits Attached Encrustation	1792	M 2
101.4	DAE	Deposits Attached Encrustation	1832	M 2
112.1	CM	Crack Multiple	1931	S 3
112.9	TBD	Tap Break-in/Hammer Defective	1979	M 3
120.5	FM	Fracture Multiple	2154	S 4
121.5	TFD	Tap Factory Defective	2181	M 3
122.7	CM	Crack Multiple	2246	S 3
124.9	CL	Crack Longitudinal	2285	S 2
124.9	DAE	Deposits Attached Encrustation	2295	M 2
129.1	CM	Crack Multiple	2357	S 3
129.1	DAE	Deposits Attached Encrustation	2372	M 2
130.9	B	Broken	2450	S 4
130.9	DAE	Deposits Attached Encrustation	2468	M 2
132.0	TFD	Tap Factory Defective	2499	M 3
133.4	FM	Fracture Multiple	2539	S 4
143.5	CM	Crack Multiple	2678	S 3
143.9	DAE	Deposits Attached Encrustation	2706	M 2
154.4	DAE	Deposits Attached Encrustation	2801	M 2
165.2	FM	Fracture Multiple	2930	S 4
167.4	CM	Crack Multiple	3006	S 3
167.4	MCU	Miscellaneous Camera Underwater	3015	M 4
167.4	MWL	Miscellaneous Water Level	3026	NA
169.4	FM	Fracture Multiple	3083	S 4
170.1	DAE	Deposits Attached Encrustation	3113	M 2
170.6	TFD	Tap Factory Defective	3136	M 3
172.4	SSS	Surface Damage Surface Spalling	3233	S 2
172.4	DAE	Deposits Attached Encrustation	3256	M 2
173.0	TBI	Tap Break-in Intruding	3286	M 2
173.0	ISZ	Intruding Sealing Material Other	3325	M 2
175.9	SSS	Surface Damage Surface Spalling	3394	S 2
176.3	MCU	Miscellaneous Camera Underwater	3417	M 4


177.8	CM	Crack Multiple	3462	S 3
184.6	RFJ	Roots Fine Joint	3602	M 1
186.8	FM	Fracture Multiple	3680	S 4
186.8	JAL	Joint Angular Large	3691	S 4
189.2	MCU	Miscellaneous Camera Underwater	3732	M 4
189.2	RFJ	Roots Fine Joint	3739	M 1
191.1	RFJ	Roots Fine Joint	3817	M 1
191.1	FM	Fracture Multiple	3830	S 4
193.6	RTJ	Roots Tap Joint	3901	M 2
193.6	DSF(F01)	Deposits Settled Fine	3923	M 2
195.3	AMH	Manhole	4017	NA

**M-504-076**




Code: **AMH**  
Description: **Manhole**

Distance (ft): **.0**  
Structural Grade: **0**  
O&M Grade: **0**  
Clock Start/From:  
Clock To:  
1st Value:  
2nd Value:  
Value Percent:  
Continuous Index:  
Within 8" of Joint: **NO**  
Remarks: **M-504-077**



Code: **MWL**  
Description: **Miscellaneous Water Level**


Distance (ft): **.0**  
Structural Grade: **0**  
O&M Grade: **0**  
Clock Start/From:  
Clock To:  
1st Value:  
2nd Value:  
Value Percent: **10.000**  
Continuous Index:  
Within 8" of Joint: **NO**  
Remarks:



Code: **CM**  
Description: **Crack Multiple**

Distance (ft): **.0**  
Structural Grade: **3**  
O&M Grade: **0**  
Clock Start/From: **2**  
Clock To: **3**  
1st Value:  
2nd Value:  
Value Percent:  
Continuous Index:  
Within 8" of Joint: **YES**  
Remarks:

---




Code: **RFJ**  
Description: **Roots Fine Joint**

Distance (ft): **5.3**  
Structural Grade: **0**  
O&M Grade: **1**  
Clock Start/From: **9**  
Clock To: **11**  
1st Value:  
2nd Value:  
Value Percent:  
Continuous Index:  
Within 8" of Joint: **YES**  
Remarks:


---






Code: **CM**  
 Description: **Crack Multiple**

Distance (ft): **5.3**  
 Structural Grade: **3**  
 O&M Grade: **0**  
 Clock Start/From: **9**  
 Clock To: **11**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:




Code: **DAE**  
 Description: **Deposits Attached Encrustation**

Distance (ft): **7.3**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **9**  
 Clock To: **3**  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:




Code: **FM**  
 Description: **Fracture Multiple**

Distance (ft): **7.3**  
 Structural Grade: **4**  
 O&M Grade: **0**  
 Clock Start/From: **9**  
 Clock To: **10**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:




Code: **DAE**  
 Description: **Deposits Attached Encrustation**

Distance (ft): **20.3**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **9**  
 Clock To: **10**  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **DAE**  
 Description: **Deposits Attached Encrustation**

Distance (ft): **20.3**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **12**  
 Clock To: **3**  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:




Code: **DSF**  
 Description: **Deposits Settled Fine**

Distance (ft): **21.0**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **5**  
 Clock To: **7**  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index: **S01**  
 Within 8" of Joint: **YES**  
 Remarks:






Code:	<b>OBM</b>
Description:	<b>Obstruction Pipe Material in Invert</b>
Distance (ft):	<b>21.0</b>
Structural Grade:	<b>0</b>
O&M Grade:	<b>2</b>
Clock Start/From:	<b>5</b>
Clock To:	<b>6</b>
1st Value:	
2nd Value:	
Value Percent:	<b>5.000</b>
Continuous Index:	
Within 8" of Joint:	<b>YES</b>
Remarks:	



Code:	<b>DAE</b>
Description:	<b>Deposits Attached Encrustation</b>
Distance (ft):	<b>22.4</b>
Structural Grade:	<b>0</b>
O&M Grade:	<b>2</b>
Clock Start/From:	<b>8</b>
Clock To:	<b>10</b>
1st Value:	
2nd Value:	
Value Percent:	<b>5.000</b>
Continuous Index:	
Within 8" of Joint:	<b>YES</b>
Remarks:	



Code: **DAE**  
 Description: **Deposits Attached Encrustation**


Distance (ft): **22.4**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **2**  
 Clock To: **4**  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **CL**  
 Description: **Crack Longitudinal**


Distance (ft): **39.5**  
 Structural Grade: **2**  
 O&M Grade: **0**  
 Clock Start/From: **3**  
 Clock To:  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:






Code: **DAE**  
 Description: **Deposits Attached Encrustation**

Distance (ft): **41.6**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **9**  
 Clock To:  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:




Code: **CL**  
 Description: **Crack Longitudinal**

Distance (ft): **41.6**  
 Structural Grade: **2**  
 O&M Grade: **0**  
 Clock Start/From: **10**  
 Clock To:  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **CL**  
 Description: **Crack Longitudinal**

Distance (ft): **41.6**  
 Structural Grade: **2**  
 O&M Grade: **0**  
 Clock Start/From: **12**  
 Clock To:  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:




Code: **DAE**  
 Description: **Deposits Attached Encrustation**

Distance (ft): **41.6**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **3**  
 Clock To:  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **RMJ**  
 Description: **Roots Medium Joint**


Distance (ft): **56.1**  
 Structural Grade: **0**  
 O&M Grade: **3**  
 Clock Start/From: **11**  
 Clock To: **1**  
 1st Value:  
 2nd Value:  
 Value Percent: **10.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **RFJ**  
 Description: **Roots Fine Joint**


Distance (ft): **58.7**  
 Structural Grade: **0**  
 O&M Grade: **1**  
 Clock Start/From: **11**  
 Clock To: **1**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:






Code: **CL**  
 Description: **Crack Longitudinal**

Distance (ft): **67.3**  
 Structural Grade: **2**  
 O&M Grade: **0**  
 Clock Start/From: **2**  
 Clock To:  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:




Code: **DAE**  
 Description: **Deposits Attached Encrustation**

Distance (ft): **77.8**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **9**  
 Clock To:  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **CM**  
 Description: **Crack Multiple**


Distance (ft): **82.2**  
 Structural Grade: **3**  
 O&M Grade: **0**  
 Clock Start/From: **11**  
 Clock To: **2**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **DAE**  
 Description: **Deposits Attached Encrustation**


Distance (ft): **86.5**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **9**  
 Clock To:  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:






Code: **B**  
 Description: **Broken**

Distance (ft): **90.3**  
 Structural Grade: **4**  
 O&M Grade: **0**  
 Clock Start/From: **8**  
 Clock To: **4**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:




Code: **DAE**  
 Description: **Deposits Attached Encrustation**

Distance (ft): **90.6**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **1**  
 Clock To: **4**  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:




Code: **TFD**  
 Description: **Tap Factory Defective**

Distance (ft): **91.7**  
 Structural Grade: **0**  
 O&M Grade: **3**  
 Clock Start/From: **12**  
 Clock To:  
 1st Value: **6.000**  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks: **LOOKS TO BE CAPPED**




Code: **RFL**  
 Description: **Roots Fine Lateral**

Distance (ft): **91.7**  
 Structural Grade: **0**  
 O&M Grade: **1**  
 Clock Start/From: **11**  
 Clock To: **1**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **NO**  
 Remarks:



Code: **DAE**  
 Description: **Deposits Attached Encrustation**


Distance (ft): **97.2**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **10**  
 Clock To: **11**  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **CM**  
 Description: **Crack Multiple**

Distance (ft): **99.4**  
 Structural Grade: **3**  
 O&M Grade: **0**  
 Clock Start/From: **10**  
 Clock To: **1**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:






Code: **DAE**  
Description: **Deposits Attached Encrustation**

Distance (ft): **99.4**  
Structural Grade: **0**  
O&M Grade: **2**  
Clock Start/From: **10**  
Clock To:  
1st Value:  
2nd Value:  
Value Percent: **5.000**  
Continuous Index:  
Within 8" of Joint: **YES**  
Remarks:


---



Code: **DAE**  
Description: **Deposits Attached Encrustation**


Distance (ft): **101.4**  
Structural Grade: **0**  
O&M Grade: **2**  
Clock Start/From: **9**  
Clock To:  
1st Value:  
2nd Value:  
Value Percent: **5.000**  
Continuous Index:  
Within 8" of Joint: **YES**  
Remarks:

---



Code: **CM**  
 Description: **Crack Multiple**


Distance (ft): **112.1**  
 Structural Grade: **3**  
 O&M Grade: **0**  
 Clock Start/From: **11**  
 Clock To: **1**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **TBD**  
 Description: **Tap Break-in/Hammer Defective**

Distance (ft): **112.9**  
 Structural Grade: **0**  
 O&M Grade: **3**  
 Clock Start/From: **12**  
 Clock To:  
 1st Value: **6.000**  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks: **Defective**






Code: **FM**  
 Description: **Fracture Multiple**

Distance (ft): **120.5**  
 Structural Grade: **4**  
 O&M Grade: **0**  
 Clock Start/From: **11**  
 Clock To: **1**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **TFD**  
 Description: **Tap Factory Defective**

Distance (ft): **121.5**  
 Structural Grade: **0**  
 O&M Grade: **3**  
 Clock Start/From: **11**  
 Clock To:  
 1st Value: **6.000**  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks: **CONSTANTLY RUNNING WATER**




Code: **CM**  
 Description: **Crack Multiple**

Distance (ft): **122.7**  
 Structural Grade: **3**  
 O&M Grade: **0**  
 Clock Start/From: **9**  
 Clock To: **12**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:




Code: **CL**  
 Description: **Crack Longitudinal**

Distance (ft): **124.9**  
 Structural Grade: **2**  
 O&M Grade: **0**  
 Clock Start/From: **12**  
 Clock To:  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:




Code:	<b>DAE</b>
Description:	<b>Deposits Attached Encrustation</b>
Distance (ft):	<b>124.9</b>
Structural Grade:	<b>0</b>
O&M Grade:	<b>2</b>
Clock Start/From:	<b>12</b>
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	<b>5.000</b>
Continuous Index:	
Within 8" of Joint:	<b>YES</b>
Remarks:	




Code:	<b>CM</b>
Description:	<b>Crack Multiple</b>
Distance (ft):	<b>129.1</b>
Structural Grade:	<b>3</b>
O&M Grade:	<b>0</b>
Clock Start/From:	<b>11</b>
Clock To:	<b>1</b>
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	<b>YES</b>
Remarks:	






Code: **DAE**  
 Description: **Deposits Attached Encrustation**

Distance (ft): **129.1**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **10**  
 Clock To: **11**  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **B**  
 Description: **Broken**


Distance (ft): **130.9**  
 Structural Grade: **4**  
 O&M Grade: **0**  
 Clock Start/From: **10**  
 Clock To: **3**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **DAE**  
 Description: **Deposits Attached Encrustation**

Distance (ft): **130.9**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **12**  
 Clock To: **3**  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:

---




Code: **TFD**  
 Description: **Tap Factory Defective**

Distance (ft): **132.0**  
 Structural Grade: **0**  
 O&M Grade: **3**  
 Clock Start/From: **12**  
 Clock To:  
 1st Value: **6.000**  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks: **LOOKS TO BE CAPPED**

---





Code: **FM**  
Description: **Fracture Multiple**

Distance (ft): **133.4**  
Structural Grade: **4**  
O&M Grade: **0**  
Clock Start/From: **12**  
Clock To: **3**  
1st Value:  
2nd Value:  
Value Percent:  
Continuous Index:  
Within 8" of Joint: **YES**  
Remarks:


---



Code: **CM**  
Description: **Crack Multiple**

Distance (ft): **143.5**  
Structural Grade: **3**  
O&M Grade: **0**  
Clock Start/From: **9**  
Clock To: **3**  
1st Value:  
2nd Value:  
Value Percent:  
Continuous Index:  
Within 8" of Joint: **YES**  
Remarks:


---



Code: **DAE**  
 Description: **Deposits Attached Encrustation**

Distance (ft): **143.9**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **1**  
 Clock To: **3**  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:


---



Code: **DAE**  
 Description: **Deposits Attached Encrustation**


Distance (ft): **154.4**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **9**  
 Clock To: **10**  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:

---



Code: **FM**  
 Description: **Fracture Multiple**


Distance (ft): **165.2**  
 Structural Grade: **4**  
 O&M Grade: **0**  
 Clock Start/From: **10**  
 Clock To: **1**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **CM**  
 Description: **Crack Multiple**

Distance (ft): **167.4**  
 Structural Grade: **3**  
 O&M Grade: **0**  
 Clock Start/From: **11**  
 Clock To: **1**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:






Code: **MCU**  
Description: **Miscellaneous Camera Underwater**

Distance (ft): **167.4**  
Structural Grade: **0**  
O&M Grade: **4**  
Clock Start/From:  
Clock To:  
1st Value:  
2nd Value:  
Value Percent:  
Continuous Index:  
Within 8" of Joint: **NO**  
Remarks: **Out at 169.4**


---



Code: **MWL**  
Description: **Miscellaneous Water Level**


Distance (ft): **167.4**  
Structural Grade: **0**  
O&M Grade: **0**  
Clock Start/From:  
Clock To:  
1st Value:  
2nd Value:  
Value Percent: **25.000**  
Continuous Index:  
Within 8" of Joint: **NO**  
Remarks:

---




Code: **FM**  
 Description: **Fracture Multiple**

Distance (ft): **169.4**  
 Structural Grade: **4**  
 O&M Grade: **0**  
 Clock Start/From: **10**  
 Clock To: **3**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **DAE**  
 Description: **Deposits Attached Encrustation**

Distance (ft): **170.1**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **1**  
 Clock To:  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **TFD**  
Description: **Tap Factory Defective**

Distance (ft): **170.6**  
Structural Grade: **0**  
O&M Grade: **3**  
Clock Start/From: **12**  
Clock To:  
1st Value: **6.000**  
2nd Value:  
Value Percent:  
Continuous Index:  
Within 8" of Joint: **YES**  
Remarks: **Defective**

---




Code: **SSS**  
Description: **Surface Damage Surface Spalling**


Distance (ft): **172.4**  
Structural Grade: **2**  
O&M Grade: **0**  
Clock Start/From: **12**  
Clock To: **2**  
1st Value:  
2nd Value:  
Value Percent:  
Continuous Index:  
Within 8" of Joint: **NO**  
Remarks:

---






Code:	<b>DAE</b>
Description:	<b>Deposits Attached Encrustation</b>
Distance (ft):	<b>172.4</b>
Structural Grade:	<b>0</b>
O&M Grade:	<b>2</b>
Clock Start/From:	<b>11</b>
Clock To:	<b>3</b>
1st Value:	
2nd Value:	
Value Percent:	<b>5.000</b>
Continuous Index:	
Within 8" of Joint:	<b>YES</b>
Remarks:	



Code:	<b>TBI</b>
Description:	<b>Tap Break-in Intruding</b>
Distance (ft):	<b>173.0</b>
Structural Grade:	<b>0</b>
O&M Grade:	<b>2</b>
Clock Start/From:	<b>1</b>
Clock To:	
1st Value:	<b>6.000</b>
2nd Value:	<b>1.000</b>
Value Percent:	
Continuous Index:	
Within 8" of Joint:	<b>NO</b>
Remarks:	<b>ROOTS GROWING IN THE TAP</b>




Code: **ISZ**  
 Description: **Intruding Sealing Material Other**

Distance (ft): **173.0**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **11**  
 Clock To: **12**  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index:  
 Within 8" of Joint: **NO**  
 Remarks: **TAP SEAL HANGING INTO THE MAIN**




Code: **SSS**  
 Description: **Surface Damage Surface Spalling**

Distance (ft): **175.9**  
 Structural Grade: **2**  
 O&M Grade: **0**  
 Clock Start/From: **11**  
 Clock To:  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:




Code:	<b>MCU</b>
Description:	<b>Miscellaneous Camera Underwater</b>
Distance (ft):	<b>176.3</b>
Structural Grade:	<b>0</b>
O&M Grade:	<b>4</b>
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	<b>NO</b>
Remarks:	<b>Out at 176.9</b>




Code:	<b>CM</b>
Description:	<b>Crack Multiple</b>
Distance (ft):	<b>177.8</b>
Structural Grade:	<b>3</b>
O&M Grade:	<b>0</b>
Clock Start/From:	<b>12</b>
Clock To:	<b>1</b>
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	<b>YES</b>
Remarks:	






Code: **RFJ**  
 Description: **Roots Fine Joint**

Distance (ft): **184.6**  
 Structural Grade: **0**  
 O&M Grade: **1**  
 Clock Start/From: **11**  
 Clock To:  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:




Code: **FM**  
 Description: **Fracture Multiple**

Distance (ft): **186.8**  
 Structural Grade: **4**  
 O&M Grade: **0**  
 Clock Start/From: **12**  
 Clock To: **3**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **JAL**  
 Description: **Joint Angular Large**

Distance (ft): **186.8**  
 Structural Grade: **4**  
 O&M Grade: **0**  
 Clock Start/From:  
 Clock To:  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **NO**  
 Remarks:



Code: **MCU**  
 Description: **Miscellaneous Camera Underwater**

Distance (ft): **189.2**  
 Structural Grade: **0**  
 O&M Grade: **4**  
 Clock Start/From:  
 Clock To:  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **NO**  
 Remarks: **Out at 189.6**



Code: **RFJ**  
 Description: **Roots Fine Joint**


Distance (ft): **189.2**  
 Structural Grade: **0**  
 O&M Grade: **1**  
 Clock Start/From: **12**  
 Clock To:  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **RFJ**  
 Description: **Roots Fine Joint**

Distance (ft): **191.1**  
 Structural Grade: **0**  
 O&M Grade: **1**  
 Clock Start/From: **12**  
 Clock To: **1**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:





Code: **FM**  
 Description: **Fracture Multiple**

Distance (ft): **191.1**  
 Structural Grade: **4**  
 O&M Grade: **0**  
 Clock Start/From: **1**  
 Clock To: **2**  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **RTJ**  
 Description: **Roots Tap Joint**


Distance (ft): **193.6**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **9**  
 Clock To: **3**  
 1st Value:  
 2nd Value:  
 Value Percent: **50.000**  
 Continuous Index:  
 Within 8" of Joint: **YES**  
 Remarks:



Code: **DSF**  
 Description: **Deposits Settled Fine**

Distance (ft): **193.6**  
 Structural Grade: **0**  
 O&M Grade: **2**  
 Clock Start/From: **5**  
 Clock To: **7**  
 1st Value:  
 2nd Value:  
 Value Percent: **5.000**  
 Continuous Index: **F01**  
 Within 8" of Joint: **YES**  
 Remarks:

---



Code: **AMH**  
 Description: **Manhole**

Distance (ft): **195.3**  
 Structural Grade: **0**  
 O&M Grade: **0**  
 Clock Start/From:  
 Clock To:  
 1st Value:  
 2nd Value:  
 Value Percent:  
 Continuous Index:  
 Within 8" of Joint: **NO**  
 Remarks: **M-504-076**