Date:	04/26/2018	Weather:		Coding:	PACP 6.0
Pipe Length (f	t):	Owner:	City of Hobart	Pre Clean:	No Pre-Cleaning
P.O.#:	99	Surveyor:	M. Pielacha	PSR:	P-505-005-004
Customer:	City of Hobart	Clean Date:		Shape:	С
Street:	3rd Place		Flow Control:	Not Controlled	ł
City:	Hobart, IN		Year Renewed:		
Location:	Light Highway		Tape/Media #:	DEP 99	
Purpose:	Routine Assessme	nt	Dia/Height:	15"	
Use:	Sanitary		Material:	VCP	
Drain Area:			Lining:		
Category:	NA				
Comment:	YES501824 Submit	tal 2			
Location Deta	ils:		Direction of Surve	y: Upstream	
US MH:	M-505-005	DS MH:	M-505-004	Total Length Surveyed (ft): 122.5
D&M Index:	3.00	O&M Quick:	3300	O&M Rating:	9.00
Structural Index	c: 0.00	 Structural Qui	ick: 0000	Structural Rating:	0.00
Overall Index:	3.00	Overall Quick:	. 3300	Overall Rating:	9.00

VI-505-004	.0	AMH			
	.0	АМН			
		,	Manhole	0	NA
	.0	MWL	Water Level	10	NA
	15.6	TFC	Tap Factory Capped	45	NA
	33.8	TBD	Tap Break-in Defective	100	M 3
	33.8	RML	Roots Medium Lateral	114	M 3
	71.9	TF	Tap Factory	205	NA
	75.2	TFA	Tap Factory Active	221	NA
	83.3	MMC	Material Change	269	NA
	87.6	ТВ	Tap Break-in	289	NA
5 I I 🛛	88.5	MMC	Material Change	311	NA
	117.8	DSF(S01)	Deposits Settled Fine	397	M 3
	122.5	DSF(F01)	Deposits Settled Fine	573	M 3
	122.5	MSA	Abandoned Survey	578	NA



Code: Description:	AMH Manhole
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-505-004

Thursday, May 4, 2023



Code:	MWL
Description:	Water Level
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	10.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Code: Description:	TFC Tap Factory Capped
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value:	15.6 0 0 9 4.000
Value Percent: Continuous Index: Within 8" of Joint: Remarks:	NO



TBD Tap Break-in Defective
33.8
0
3
10
4.000
NO
Defective



Code: Description:	RML Roots Medium Lateral
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index: Within 8" of Joint: Remarks:	33.8 0 3 10 5.000 NO
Kernarks.	




Code:	TF
Description:	Tap Factory
Distance (ft):	71.9
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	10
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Code: Description:	TFA Tap Factory Active
Distance (ft):	75.2
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	3
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Code: Description:	MMC Material Change
Distance (ft):	83.3
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	рус



Code: Description:	TB Tap Break-in
Distance (ft):	87.6
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	9
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Code: Description:	MMC Material Change
Distance (ft):	88.5
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	vср



Code: Description:	DSF Deposits Settled Fine
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index: Within 8" of Joint: Remarks:	117.8 0 3 4 8 15.000 S01 YES



Code:	DSF
Description:	Deposits Settled Fine
	(1 1 1
Distance (ft):	122.5
Structural Grade:	0
O&M Grade:	3
Clock Start/From:	4
Clock To:	8
1st Value:	
2nd Value:	
Value Percent:	20.000
Continuous Index:	F01
Within 8" of Joint:	NO
Remarks:	



Code: Description:	MSA Abandoned Survey
Distance (ft):	122.5
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	sediment