Profile/Photo Observation Report



Date: 10/08/2018 Weather: **PACP 6.0** Coding: Pipe Length (ft): 248.6 Owner: NA Pre Clean: **Not Known** P.O.#: PSR: P-507-014-013 Surveyor: Selasie Honu

Customer: Clean Date: 01/01/1900 Shape: C

Street: Csokasy Ln. Flow Control: Not Controlled

City: Hobart, IN Year Renewed:
Location: Light Highway Tape/Media #:

Purpose: Routine Assessment Dia/Height: 10"
Use: Sanitary Material: VCP

Drain Area: **NA** Lining:

Category: NA

Comment:

Location Details: Direction of Survey: Downstream

US MH: M-507-013 DS MH: M-507-014 Total Length Surveyed (ft): 76.1

0000 0.00 0.00 O&M Index: O&M Quick: O&M Rating: 0.00 0000 0.00 Structural Quick: Structural Rating: Structural Index: 0.00 0000 0.00 Overall Rating: Overall Index: Overall Quick:

	Position	Code	Observation	Video (sec)	Grade
л (507- 013	3				
	.0	AMH	Manhole	10	NA
	.0	MWL	Water Level	21	NA
\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	39.1	TF	Tap Factory	111	NA
	40.7	TF	Tap Factory	125	NA
	76.1	MSA	Abandoned Survey	207	NA

Code:



Description:	Manhole
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-507-013

AMH



Code: MWL

Description: Water Level

Distance (ft): .0
Structural Grade: 0
O&M Grade: 0
Clock Start/From:

Clock Start/From

1st Value: 2nd Value:

Value Percent: 5

Continuous Index:

Within 8" of Joint:

Remarks:

5.000

NO

Code: TF

Description: Tap Factory



Distance (ft): 39.1
Structural Grade: 0

O&M Grade: 0


Clock Start/From: 3

Clock To:

Remarks:

1st Value: **4.000**

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:



Code: **TF**

Description: Tap Factory

Distance (ft): 40.7
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 9

Clock To:

1st Value:

4.000

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:

Code: MSA

Description: Abandoned Survey



Distance (ft): **76.1**Structural Grade: **0**O&M Grade: **0**

Clock Start/From:

Clock To:
1st Value:
2nd Value:
Value Percent:
Continuous Index:

Within 8" of Joint: NO

Remarks: camera stopped