Profile/Photo Observation Report



Date: **04/12/2018** Weather: Coding: **PACP 6.0**

Pipe Length (ft): 24.4 Owner: NA Pre Clean: No Pre-Cleaning
P.O.#: Surveyor: Jen Costello PSR: P-507-039.5-083

Customer: Clean Date: 01/01/1900 Shape: C

Street: W 10TH PL Flow Control: Not Controlled

City: Hobart, IN Year Renewed: Location: Yard Tape/Media #:

Purpose: Routine Assessment Dia/Height: 12"
Use: Sanitary Material: VCP

Drain Area: **NA** Lining:

Category: NA

Comment:


Location Details: Direction of Survey: Upstream

US MH: M-507-039.5 DS MH: M-507-083 Total Length Surveyed (ft): 19.5

O&M Index:3.00O&M Quick:4131O&M Rating:9.00Structural Index:4.00Structural Quick:4100Structural Rating:4.00Overall Index:3.25Overall Quick:4231Overall Rating:13.00


| | ion Code | Observation | Video (sec) | Grade |
|---------|----------|--------------------------------|-------------|-------|
| 507-083 | | | | |
| 0. | AMH | Manhole | 10 | NA |
| .0 | MWL | Water Level | 21 | NA |
| 0. | DAE | Deposits Attached Encrustation | 33 | M 2 |
| 0. | FM | Fracture Multiple | 44 | S 4 |
| \.0 | IR | Infil Runner | 55 | M 4 |
| 16.1 | RMJ | Roots Medium Joint | 99 | M 3 |
| 19.5 | AMH | Manhole | 117 | NA |
| | | | | |
| | | | | |

Code:



| Description: | Manhole |
|---------------------|-----------|
| | |
| Distance (ft): | .0 |
| Structural Grade: | 0 |
| O&M Grade: | 0 |
| Clock Start/From: | |
| Clock To: | |
| 1st Value: | |
| 2nd Value: | |
| Value Percent: | |
| Continuous Index: | |
| Within 8" of Joint: | NO |
| Remarks: | M-507-083 |
| | |

 AMH



Code: MWL

Description: Water Level

Distance (ft): .0
Structural Grade: 0
O&M Grade: 0
Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent:


Continuous Index:

Within 8" of Joint:

Remarks:

5.000

NO



Code: DAE

Description: Deposits Attached Encrustation


Distance (ft): .0
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 7
Clock To: 5
1st Value:
2nd Value:

Value Percent: 10.000

Continuous Index:

Within 8" of Joint: NO

Remarks:



Code: **FM**


Description: Fracture Multiple

Distance (ft): .0
Structural Grade: 4
O&M Grade: 0
Clock Start/From: 10
Clock To: 2
1st Value:
2nd Value:

Continuous Index: Within 8" of Joint:

Value Percent:

Remarks:



Code: IR

Description: Infil Runner

Distance (ft): .0
Structural Grade: 0
O&M Grade: 4
Clock Start/From: 1
Clock To:
1st Value:

Value Percent: Continuous Index: Within 8" of Joint:

Remarks:

2nd Value:



Code: RMJ

Description: Roots Medium Joint

Distance (ft): 16.1
Structural Grade: 0
O&M Grade: 3
Clock Start/From: 6
Clock To: 12

1st Value: 2nd Value:

Value Percent: 40.000

Continuous Index:

Within 8" of Joint:

YES

Remarks:



Code: AMH
Description: Manhole

Distance (ft): 19.5
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To:
1st Value:
2nd Value:
Value Percent:
Continuous Index:

Within 8" of Joint: NO

Remarks: M-507-039.5