## **Profile/Photo Observation Report**

Sanitary

Use:



Date: 04/23/2018 Weather: **PACP 6.0** Coding: Pipe Length (ft): 285.9 Owner: NA Pre Clean: **Not Known** P.O.#: Jen Costello PSR: P-604-039-034 Surveyor:

Customer: Clean Date: 01/01/1900 Shape:

Summerlin Flow Control: **Not Controlled** Street: City: Hobart, IN Year Renewed:

Tape/Media #: Location: **Light Highway** Purpose: **Not Known** Dia/Height: 12" Material: **VCP** 

NA Drain Area: Lining:

NA Category:

Comment: **Location Details:** Direction of Survey: **Downstream** 

US MH: M-604-039 Total Length Surveyed (ft): M-604-034 DS MH: 283.8

3222 2.50 10.00 O&M Index: O&M Quick: O&M Rating: 0.00 0000 0.00 Structural Quick: Structural Rating: Structural Index: 2.50 3222 10.00 Overall Quick: Overall Rating: Overall Index:


	Position	Code	Observation	Video (sec)	Grade
604-0	34				
$\overline{}$	.0	AMH	Manhole	10	NA
ш	\0	MWL	Water Level	21	NA
ш	101.6	TFD	Tap Factory Defective	236	M 2
ш	101.6	RML	Roots Medium Lateral	247	M 3
ш	121.7	TFD	Tap Factory Defective	299	M 2
ш	121.7	RML	Roots Medium Lateral	310	M 3
Ш	172.4	TFA	Tap Factory Active	425	NA
$\mathbb{H}IIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIII$	192.4	TFA	Tap Factory Active	480	NA
$\square$	235.5	TFA	Tap Factory Active	579	NA
Ш	283.8	AMH	Manhole	687	NA

Code:



Description:	Manhole
Distance (ft):	.0
Structural Grade: O&M Grade:	0
Clock Start/From: Clock To:	
1st Value: 2nd Value:	
Value Percent:	
Within 8" of Joint: Remarks:	NO M-604-034

 $\mathsf{AMH}$ 



Code: MWL

Description: **Water Level** 

Distance (ft): .0 Structural Grade: 0 O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent:

Continuous Index:

Within 8" of Joint: NO

Remarks:

5.000



Code: **TFD** 

Description: **Tap Factory Defective** 

Distance (ft): 101.6 Structural Grade: 0 O&M Grade: 2 Clock Start/From: 3

Clock To:

1st Value: 4.000

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks: Roots



Code: RML

Description: Roots Medium Lateral

Distance (ft): 101.6
Structural Grade: 0
O&M Grade: 3
Clock Start/From: 3
Clock To: 5

1st Value: 2nd Value:

Value Percent: 20.000

Continuous Index:

Within 8" of Joint:

Remarks:

NO



Code: **TFD** 

Description: Tap Factory Defective

Distance (ft): 121.7
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 9

Clock To:

1st Value: **4.000** 

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks: roots



Code: RML

Description: Roots Medium Lateral

Distance (ft): 121.7
Structural Grade: 0
O&M Grade: 3
Clock Start/From: 7
Clock To: 9

1st Value: 2nd Value:


Value Percent: 10.000

Continuous Index:

Within 8" of Joint:

Remarks:

NO



Code: TFA

Description: Tap Factory Active

Distance (ft): 172.4
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 3

Clock To:

1st Value: **4.000** 

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:



Code: TFA

Description: Tap Factory Active

4.000

Distance (ft): 192.4
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 9

Clock To:

1st Value:

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:

Code: TFA

Description: Tap Factory Active



Distance (ft): 235.5
Structural Grade: 0
O&M Grade: 0

Clock Start/From: 3
Clock To:

1st Value: **4.000** 

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:



Code: AMH
Description: Manhole

Distance (ft): 283.8
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: NO

Remarks: M-604-039