Profile/Photo Observation Report



Date: 04/25/2018 Weather: Coding: PACP 6.0

Pipe Length (ft): 216.5 Owner: NA Pre Clean: Not Known

 P.O.#:
 Surveyor:
 Jen Costello
 PSR:
 P-604-070-046

 Customer:
 Clean Date:
 01/01/1900
 Shape:
 C

Street: N WASHINGTON ST & W CLEVELAND Flow Control: Not Controlled

City: Hobart, IN Year Renewed:
Location: Light Highway Tape/Media #:

Purpose: Not Known Dia/Height: 12"
Use: Sanitary Material: VCP

Drain Area: **NA** Lining:

Category: NA

Comment:

Location Details: Direction of Survey: **Downstream**

US MH: M-604-070 DS MH: M-605-046 Total Length Surveyed (ft): 23.7

2.58 31.00 O&M Index: O&M Quick: O&M Rating: 3.00 3200 6.00 Structural Quick: Structural Rating: Structural Index: 2.64 37.00 Overall Quick: Overall Rating: Overall Index:

070		Observation	Video (sec)	Grade
				
0.	AMH	Manhole	10	NA
0.	MWL	Water Level	21	NA
_	RMJ	Roots Medium Joint	33	M 3
2.6	FL(S01)	Fracture Longitudinal	49	S 3
2.6	RMB	Roots Medium Barrel	60	M 4
5.3	RMJ(S02)	Roots Medium Joint	77	M 3
9.7	DAE	Deposits Attached Encrustation	98	M 2
/10.6	5 TFD	Tap Factory Defective	111	M 2
// 10.6	DAE	Deposits Attached Encrustation	122	M 2
12.6	5 ТВІ	Tap Break-in Intruding	138	M 2
12.6	5 FL(F01)	Fracture Longitudinal	149	S 3
// 12.6	RMJ(F02)	Roots Medium Joint	160	M 3
13.7	7 DAE	Deposits Attached Encrustation	174	M 2
15.5	5 IW(S03)	Infil Weeper	189	M 2
/ 22.0) RMJ	Roots Medium Joint	214	M 3
/ 23.7	7 RBJ	Roots Ball Joint	229	M 4
23.7	7 MSA	Abandoned Survey	240	NA
23.7	7 IW(F03)	Infil Weeper	251	M 2

Code:

Description:



Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-604-070

AMH

Manhole



Code: MWL

Description: **Water Level**

Distance (ft): .0 Structural Grade: 0 O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent:


Continuous Index:

Within 8" of Joint:

Remarks:

5.000

NO



Code: RMJ

Description: **Roots Medium Joint**

Distance (ft): .0 Structural Grade: 0 O&M Grade: 3 Clock Start/From: 8 Clock To: 4 1st Value: 2nd Value:

Value Percent: 10.000

Continuous Index:

Within 8" of Joint: YES



Code: FL

Description: Fracture Longitudinal

Distance (ft): 2.6
Structural Grade: 3
O&M Grade: 0
Clock Start/From: 12

Clock To: 1st Value: 2nd Value: Value Percent:

Continuous Index: **S01**Within 8" of Joint: **YES**

Remarks:



Code: RMB

Description: Roots Medium Barrel

NO

Distance (ft): 2.6
Structural Grade: 0
O&M Grade: 4
Clock Start/From: 12

Clock To: 1st Value: 2nd Value: Value Percent:

alue Percent: 5.000

Continuous Index:

Within 8" of Joint:



Code: RMJ

Description: Roots Medium Joint

Distance (ft): 5.3
Structural Grade: 0
O&M Grade: 3
Clock Start/From: 8
Clock To: 4
1st Value:

2nd Value:

Value Percent: 5.000
Continuous Index: S02
Within 8" of Joint: YES

Remarks:

Code: DAE

Description: Deposits Attached Encrustation



Distance (ft): 9.7
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 3
Clock To: 4
1st Value:

2nd Value: Value Percent:

lue Percent: 5.000

Continuous Index:

Within 8" of Joint: YES



Code: **TFD**

Description: Tap Factory Defective

Distance (ft): 10.6
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 2

Clock To:

1st Value: **4.000**

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks: dae



Code: DAE

Description: Deposits Attached Encrustation

Distance (ft): 10.6
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 3
Clock To: 4
1st Value:
2nd Value:

Value Percent: 5.000

Continuous Index:

Within 8" of Joint: NO



Code: TBI

Description: Tap Break-in Intruding

Distance (ft): 12.6
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 10

Clock To:

 1st Value:
 4.000

 2nd Value:
 2.000

Value Percent: Continuous Index: Within 8" of Joint:

Remarks:



Code: FL

Description: Fracture Longitudinal

Distance (ft): 12.6
Structural Grade: 3
O&M Grade: 0
Clock Start/From: 12
Clock To:

1st Value:
2nd Value:
Value Percent:

Continuous Index: F01
Within 8" of Joint: YES



Code: RMJ

Description: Roots Medium Joint

Distance (ft): 12.6
Structural Grade: 0
O&M Grade: 3
Clock Start/From: 8
Clock To: 4
1st Value:

1st Value: 2nd Value:

Value Percent: 5.000
Continuous Index: F02
Within 8" of Joint: YES

Remarks:

Code: DAE

Description: Deposits Attached Encrustation



Distance (ft): 13.7
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 3
Clock To: 4

1st Value: 2nd Value:

Value Percent: 10.000

Continuous Index:

Within 8" of Joint: YES



Code: IW

Description: Infil Weeper

Distance (ft): 15.5
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 8
Clock To: 4


1st Value: 2nd Value: Value Percent:

Continuous Index: S03
Within 8" of Joint: YES

Remarks:

Code: RMJ

Description: Roots Medium Joint



Distance (ft): 22.0
Structural Grade: 0
O&M Grade: 3
Clock Start/From: 8

Clock Start/From: 8
Clock To: 4
1st Value:

2nd Value: Value Percent:

Value Percent: 10.000

Continuous Index:

Within 8" of Joint: YES



Code: RBJ

Description: Roots Ball Joint

Distance (ft): 23.7
Structural Grade: 0
O&M Grade: 4
Clock Start/From: 12
Clock To: 12

1st Value: 2nd Value:

Value Percent: 90.000

Continuous Index:

Within 8" of Joint:

Remarks:

YES



Code: MSA

Description: Abandoned Survey

Distance (ft): 23.7
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: NO Remarks: roots



Code: IW

Description: Infil Weeper

Distance (ft): 23.7
Structural Grade: 0

O&M Grade: 2

Clock Start/From: 8

Clock To: 4

1st Value: 2

2nd Value: Value Percent:

Continuous Index: F03
Within 8" of Joint: YES