Profile/Photo Observation Report



Date: 06/21/2023 Weather: Coding: PACP 7.0

Pipe Length (ft): 155.6 Owner: City of Hobart Pre Clean: No Pre-Cleaning

P.O.#: YES502259 Surveyor: S. Bucklin PSR: M-607-072-M-607-074

Customer: City of Hobart Clean Date: Shape: C

Street: South Ash Street Flow Control: Not Controlled

City: Hobart, IN Year Renewed:
Location: Easement/Right of Way Tape/Media #:

Purpose: Routine Assessment Dia/Height: 8"
Use: Sanitary Sewage Pipe Material: PVC

Drain Area: Lining: **None**

Category: NA

Comment:

Location Details: Direction of Survey: **Upstream**

US MH: M-607-072 DS MH: M-607-074 Total Length Surveyed (ft): 155.6

2.00 2A00 22.00 O&M Index: O&M Quick: O&M Rating: 2.00 2B00 34.00 Structural Index: Structural Quick: Structural Rating: 2.00 2D00 56.00 Overall Index: Overall Quick: Overall Rating:

	Position	Code	Observation	Video (sec)	Grade
607-	074				
$\overline{}$	0. //	AMH	Manhole	0	NA
	0.	MWL	Miscellaneous Water Level	95	NA
Ш.	9.1	MWLS(S01)	Miscellaneous Water Level Sag	144	S 2
	18.6	MWLS(F01)	Miscellaneous Water Level Sag	184	S 2
ш	50.6	MWLS(S02)	Miscellaneous Water Level Sag	279	S 2
ш	91.2	MWLS(F02)	Miscellaneous Water Level Sag	411	S 2
ш	102.7	MWLS(S03)	Miscellaneous Water Level Sag	454	S 2
	102.7	DSF(S04)	Deposits Settled Fine	462	M 2
ш	135.3	MWLS(F03)	Miscellaneous Water Level Sag	577	S 2
ш	155.5	DSF(F04)	Deposits Settled Fine	672	M 2
ш	155.6	AMH	Manhole	803	NA



Code:	AMH		
Description:	Manhole		
Distance (ft):	.0		
Structural Grade:	0		
O&M Grade:	0		
Clock Start/From:			
Clock To:			
1st Value:			
2nd Value:			
Value Percent:			
Continuous Index:			
Within 8" of Joint:	NO		
Remarks:	M-607-074		



Code: MWL

Description: Miscellaneous Water Level

Distance (ft): .0
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 5.000

Continuous Index:

Within 8" of Joint: NO

Remarks:

5.000



Code: MWLS

Description: Miscellaneous Water Level Sag

Distance (ft): 9.1
Structural Grade: 2
O&M Grade: 0
Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 5.000
Continuous Index: S01
Within 8" of Joint: NO



Code: MWLS

Description: Miscellaneous Water Level Sag

Distance (ft): 18.6
Structural Grade: 2
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 5.000
Continuous Index: F01
Within 8" of Joint: NO

Remarks:



Code: MWLS

Description: Miscellaneous Water Level Sag

Distance (ft): 50.6
Structural Grade: 2
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 10.000
Continuous Index: S02
Within 8" of Joint: NO



Code: MWLS

Description: Miscellaneous Water Level Sag

Distance (ft): 91.2
Structural Grade: 2
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 10.000
Continuous Index: F02
Within 8" of Joint: NO

Remarks:



Code: MWLS

Description: Miscellaneous Water Level Sag

Distance (ft): 102.7
Structural Grade: 2
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 15.000
Continuous Index: S03
Within 8" of Joint: NO



Code: **DSF**

Description: Deposits Settled Fine

7

Distance (ft): 102.7
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 5

1st Value: 2nd Value:

Clock To:

Value Percent: 5.000
Continuous Index: S04
Within 8" of Joint: YES

Remarks:



Code: MWLS

Description: Miscellaneous Water Level Sag

Distance (ft): 135.3
Structural Grade: 2
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 15.000
Continuous Index: F03
Within 8" of Joint: NO



Code: **DSF**


Description: Deposits Settled Fine

Distance (ft): 155.5
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 5
Clock To: 7

1st Value: 2nd Value:

Value Percent: 5.000
Continuous Index: F04
Within 8" of Joint: YES

Remarks:



Code: AMH
Description: Manhole

Distance (ft): 155.6
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: NO

Remarks: M-607-072