Profile/Photo Observation Report



Profile/Photo Observation Report								
Date: Pipe Length (ft		Weather: Owner:	Hobart, I		Coding: Pre Clean:	PACP 6.0 Not Known		
P.O.#: Customer:	899_1 Hobart, IN	Surveyor: Clean Date:	M. Pielac	na	PSR: Shape:	P-705-015-016 C		
Street:	5th Street		Flow Contr	ol:	·			
City:	Hobart, IN		Year Renev					
Location:	Light Highway		Tape/Medi	a #:	899			
Purpose:	Routine Assessme	nt	Dia/Height:		8"			
Use:	Sanitary		Material:		VCP			
Drain Area:			Lining:					
Category:	NA							
Comment:								
Location Details:			Direction of Survey:		Downstream			
US MH:	M-705-16	DS MH:	M-705-15	То	otal Length Surveyed (ft):	46.0		
O&M Index:	3.00	O&M Quick:		3200	O&M Rating:	6.00		
Structural Index	0.00	Structural Qu		0000	Structural Rating:	0.00		
Overall Index:	3.00	Overall Quicl		3200	Overall Rating:	6.00		

	Position	Code	Observation	Video (sec)	Grade
(-705)-16	5				
	.0	AMH	Manhole	0	NA
	.0	MWL	Water Level	8	NA
ш	34.8	DSF(S01)	Deposits Settled Fine	88	M 3
ш	46.0	DSF(F01)	Deposits Settled Fine	286	M 4
ш	46.0	MSA	Abandoned Survey	304	NA
ш					

Code:



Description:	Manhole	
Distance (ft):	.0	
Structural Grade:	0	
O&M Grade:	0	
Clock Start/From:		
Clock To:		
1st Value:		
2nd Value:		
Value Percent:		
Continuous Index:		
Within 8" of Joint:	NO	
Remarks:	M-705-16	

 AMH



Code: MWL

Description: Water Level

Distance (ft): .0
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 10.000

Continuous Index:

Within 8" of Joint: NO

Remarks:




Description: Deposits Settled Fine

Distance (ft): 34.8
Structural Grade: 0
O&M Grade: 3
Clock Start/From: 4
Clock To: 8

1st Value: 2nd Value:

Value Percent: 20.000
Continuous Index: S01
Within 8" of Joint: YES

Remarks:





Code: **DSF**

Description: Deposits Settled Fine

Distance (ft): 46.0
Structural Grade: 0
O&M Grade: 4
Clock Start/From: 4
Clock To: 8

1st Value: 2nd Value:

Value Percent: 30.000
Continuous Index: F01
Within 8" of Joint: NO

Remarks:



Code: MSA

Description: Abandoned Survey

Distance (ft): 46.0
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To:
1st Value:
2nd Value:
Value Percent:
Continuous Index:

Within 8" of Joint: NO

Remarks: deep sediment