Date:	05/03/2018	Weather:			Coding:	PACP 6.0
Pipe Length (f	ít):	Owner:	City of Hob	art	Pre Clean:	No Pre-Cleaning
P.O.#:	186	Surveyor:	M. Pielacha	I	PSR:	P-705-021-020
Customer:	City of Hobart	Clean Date:			Shape:	С
Street:	6th Street		Flow Control	:	Not Controlled	
City:	Hobart, IN		Year Renewe	d:		
Location:	Light Highway		Tape/Media	#:	DEP 186	
Purpose:	Routine Assessment	:	Dia/Height:		6"	
Use:	Sanitary		Material:		VCP	
Drain Area:			Lining:			
Category:	NA					
Comment:	5-21-2018					
Location Deta	ils:		Direction of S	Survey:	Downstream	
US MH:	M-705-020	DS MH:	M-705-021	То	otal Length Surveyed (ft)	33.9
0&M Index:	2.23	O&M Quick:		3815	O&M Rating:	29.00
Structural Index	c 0.00	Structural Qu		0000	Structural Rating:	0.00
Overall Index:	2.23	Overall Quic		3815	Overall Rating:	29.00

	Position	Code	Observation	Video (sec)	Grade
M(70	5-020				
	0.	AMH	Manhole	0	NA
- 11	.0	MWL	Water Level	7	NA
- 11	0.	DSF(S01)	Deposits Settled Fine	14	M 3
	5.0	RFJ(SO2)	Roots Fine Joint	67	M 1
- 11	30.6	RFJ(F02)	Roots Fine Joint	149	M 1
- 11	30.6	TF	Tap Factory	155	NA
- 11	32.8	TF	Tap Factory	186	NA
- 11	33.1	RMJ	Roots Medium Joint	205	M 3
- 11	33.9	DSF(F01)	Deposits Settled Fine	252	M 3
5	33.9	MSA	Abandoned Survey	255	NA
Camera Direction					
M-70	5-021				



Code: Description:	AMH Manhole
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-705-020

Thursday, May 4, 2023



Code:	MWL
Description:	Water Level
Distance (ft):	0
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	10.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Distance (ft): .0	Code:	DSF
Structural Grade: 0	Description:	Deposits Settled Fine
O&M Grade:3Clock Start/From:4Clock To:81st Value:-2nd Value:-Value Percent:15.000Continuous Index:S01Within 8" of Joint:YESRemarks:-	Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index: Within 8" of Joint:	0 3 4 8 15.000 S01



Code:	RFJ
Description:	Roots Fine Joint
Distance (ft):	5.0
Structural Grade:	0
O&M Grade:	1
Clock Start/From:	7
Clock To:	5
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	S02
Within 8" of Joint:	YES
Remarks:	



Code: Description:	RFJ Roots Fine Joint
Distance (ft):	30.6
Structural Grade:	0
O&M Grade:	1
Clock Start/From:	7
Clock To:	5
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	F02
Within 8" of Joint:	YES
Remarks:	



Code:	TF
Description:	Tap Factory
Distance (ft):	30.6
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	10
Clock To:	
1st Value:	6.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Code: Description:	TF Tap Factory
Distance (ft):	32.8
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	2
Clock To:	
1st Value:	6.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Code:	RMJ
Description:	Roots Medium Joint
Distance (ft):	33.1
Structural Grade:	0
O&M Grade:	3
Clock Start/From:	1
Clock To:	5
1st Value:	
2nd Value:	
Value Percent:	20.000
Continuous Index:	
Within 8" of Joint:	YES
Remarks:	



Code: Description:	DSF Deposits Settled Fine
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index:	33.9 0 3 4 8 15.000 F01
Within 8" of Joint: Remarks:	ΝΟ



Code: Description:	MSA Abandoned Survey
Distance (ft):	33.9
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	RMJ